



**QUEEN'S
UNIVERSITY
BELFAST**

Risk-Averse Model Predictive Operation Control of Islanded Microgrids

Hans, C. A., Sopasakis, P., Raisch, J., Reincke-Collon, C., & Patrinos, P. (2019). Risk-Averse Model Predictive Operation Control of Islanded Microgrids. *IEEE Transactions on Control Systems Technology*.
<https://doi.org/10.1109/TCST.2019.2929492>

Published in:
IEEE Transactions on Control Systems Technology

Document Version:
Peer reviewed version

Queen's University Belfast - Research Portal:
[Link to publication record in Queen's University Belfast Research Portal](#)

Publisher rights
© 2019 IEEE. This work is made available online in accordance with the publisher's policies. Please refer to any applicable terms of use of the publisher.

General rights
Copyright for the publications made accessible via the Queen's University Belfast Research Portal is retained by the author(s) and / or other copyright owners and it is a condition of accessing these publications that users recognise and abide by the legal requirements associated with these rights.

Take down policy
The Research Portal is Queen's institutional repository that provides access to Queen's research output. Every effort has been made to ensure that content in the Research Portal does not infringe any person's rights, or applicable UK laws. If you discover content in the Research Portal that you believe breaches copyright or violates any law, please contact openaccess@qub.ac.uk.

Open Access
This research has been made openly available by Queen's academics and its Open Research team. We would love to hear how access to this research benefits you. – Share your feedback with us: <http://go.qub.ac.uk/oa-feedback>

Risk-Averse Model Predictive Operation Control of Islanded Microgrids

Christian A. Hans, *Student Member, IEEE*, Pantelis Sopasakis, Jörg Raisch,
Carsten Reincke-Collon and Panagiotis Patrinos, *Member, IEEE*

Abstract—In this paper we present a risk-averse model predictive control (MPC) scheme for the operation of islanded microgrids with very high share of renewable energy sources. The proposed scheme mitigates the effect of errors in the determination of the probability distribution of renewable infeed and load. This allows to use less complex and less accurate forecasting methods and to formulate low-dimensional scenario-based optimisation problems which are suitable for control applications. Additionally, the designer may trade performance for safety by interpolating between the conventional stochastic and worst-case MPC formulations. The presented risk-averse MPC problem is formulated as a mixed-integer quadratically-constrained quadratic problem and its favourable characteristics are demonstrated in a case study. This includes a sensitivity analysis that illustrates the robustness to load and renewable power prediction errors.

I. INTRODUCTION

The substitution of conventional power plants by renewable energy sources (RES) is a key element in the fight against climate change. However, it presents major challenges. The structure of power supply is expected to change from a small number of large-scale power plants to a large number of small-scale units. These will be geographically distributed over the entire electric grid. Additionally, the uncertainty in power supply of some RES will complicate the operation of the grid.

One way to tackle these challenges is to partition the electric grid into microgrids (MGs) [1]. These comprise storage, conventional and renewable units connected to each other and to loads by transmission lines [2]. MGs can be operated connected to the grid or electrically isolated (islanded) [3]. Inspired by conventional power systems, hierarchical approaches have been promoted for the control of MGs, e.g., in [4]. On the

lower control layer, typically on a timescale from milliseconds to seconds, primary control aims to provide voltage and frequency stability. Secondary control, typically on a timescale from seconds to minutes, aims at compensating frequency deviations and ensures that the voltages remain close to the desired values. Operation control, also referred to as energy management, typically acts on a timescale of minutes to fractions of hours. It aims at optimising the MG operation by providing power setpoints to the units [5]. For this task, model predictive control (MPC) approaches are considered a good choice as they allow to explicitly include constraints on the units and take into account the system dynamics. Moreover, they can be combined with forecasts of load and renewable infeed to operate the MG in an optimal way.

A. Operation control of MGs

Several approaches for the operation control of MGs have been proposed. One way to categorise them is by the way they handle uncertainties. Prominent formulations are (i) certainty-equivalent, where a deterministic system model is fully trusted, (ii) worst-case, where no probability distribution is considered, (iii) risk-neutral stochastic, where an underlying probability distribution is trusted, and (iv) risk-averse, where the underlying distribution is not fully trusted.

There is a variety of publications on operation control of MGs where a perfect forecast is assumed. For example, in [6] a certainty-equivalent approach for grid-connected MGs is proposed. Based on the assumption that the forecast generation of RES, load and the energy price are certain, in [7] an MPC is presented. For islanded MGs, an MPC approach that also assumes perfect forecasts is given in [8]. A certainty-equivalent approach that includes power flow over the lines is proposed in [9]. However, as shown in [10], in the operation of islanded MGs with high share of RES, certainty-equivalent approaches can lead to significant constraint violations.

To compensate for this lack of robustness, some authors have proposed worst-case MPC approaches for the operation of MGs. Uncertain parameters, such as model parameters [11] and forecasts [10], [12] are treated as bounded quantities and an MPC formulation is used to minimise the worst-case cost. The MPC approaches for islanded MGs in [10], [12] include power flow over the lines, power sharing of grid-forming units and curtailable renewable infeed. However, these approaches have been found to be overly conservative as they try to minimise the worst-case objective [10], [12].

The conservativeness of worst-case approaches has led to the wide adoption of stochastic methods, which consist in

C. A. Hans is with Technische Universität Berlin, Control Systems Group, Germany (e-mail: hans@control.tu-berlin.de).

P. Sopasakis is with Queen's University Belfast, School of Electronics, Electrical Engineering and Computer Science, Centre For Intelligent Autonomous Manufacturing Systems (i-AMS), Belfast, Northern Ireland, UK (e-mail: p.sopasakis@qub.ac.uk).

J. Raisch is with Technische Universität Berlin, Control Systems Group and Max-Planck-Institut für Dynamik komplexer technischer Systeme, Germany (e-mail: raisch@control.tu-berlin.de).

C. Reincke-Collon is with Aggreko plc, Germany (e-mail: carsten.reincke-collon@aggreko.com).

P. Patrinos is with KU Leuven, Department of Electrical Engineering (ESAT), Belgium (e-mail: panos.patrinos@kuleuven.be).

This work was partially supported by the German Federal Ministry for Economic Affairs and Energy (BMWi), projects No. 0324024A and 0325713A; FWO projects No. G086318N and G086518N; Fonds de la Recherche Scientifique-FNRS, Fonds Wetenschappelijk Onderzoek-Vlaanderen under EOS project No. 30468160 (SeLMA); Research Council KU Leuven C1 project No. C14/18/068.

minimising the expected value of a random cost with respect to an assumed probability distribution. There are two main approaches to modelling randomness: (i) random processes with continuous distributions and (ii) scenario trees.

In the area of microgrid control, some authors have used the assumption that all involved uncertain quantities are normally distributed [13], [14], [15], [16]. Having unbounded support, Gaussian disturbances make it impossible to satisfy state constraints uniformly; instead chance constraints can be used. Dealing with chance constraints hinges on the normality assumption and requires that the involved random processes be independent [17], [18]. An approach for chance constraints that drops the normality assumption using polynomial chaos expansions and machine learning is presented in [19].

Scenario-based approaches seem to be more popular in microgrid control [7], [16], [20], [21], [22], [23], [24]; mainly because scenario trees can be constructed from data [25], [26], [27] and the assumption of independence does not need to be imposed. In [21], a scenario-based approach combining an optimal operation scheduling with an MPC and assuming uncertain weather and load was proposed. Furthermore, [7] was extended in [22] to a two-stage stochastic MPC approach, which was formulated using scenario trees. In [23], a scenario-based optimal operation control strategy for droop controlled MGs is presented, where a heuristic particle swarm optimisation is used to minimise the expected objective value while accounting for power limitations of the transmission lines. A stochastic continuous-time rolling horizon control strategy that considers uncertain load can be found in [24]. However, this approach disregards the power flow over the transmission lines, possible power sharing among grid-forming units and the possibility to limit the power provided by RES. There exist other scenario-based approaches, e.g., [16], that account for power flow. However, [16] does not allow to limit infeed from RES. One approach that includes power flow, curtailable RES and power sharing is the scenario-based stochastic MPC presented in [20].

Scenario-based MPC approaches that minimise the expectation of the cost assume that the scenario tree offers an adequate representation of the underlying probability distribution. The realisation that this assumption does not always hold led to the emergence of risk-averse MPC [28], [29] which aims at safeguarding the controlled system from the effects of inexact knowledge of the underlying probability distribution.

B. Risk-based approaches in power systems

Risk measures stem from the domains of operations research, stochastic finance and actuarial science [30]. An example of a popular risk measure is the average value-at-risk (AVaR) [30]. When used in optimisation problems, risk measures allow to mitigate the effects of inexact knowledge of the underlying probability distributions. They bridge the gap between conservative worst-case approaches, which assume no knowledge about the underlying probability distribution and stochastic approaches, which assume perfect knowledge about it. Therefore, risk-averse approaches are suitable for practical implementations where probability distributions are not known

exactly. In the case of operation management of MGs it is likely that the predicted load and renewable infeed are uncertain and inaccurately estimated probability distribution. Such errors in the probability distribution can have a high impact on the controlled system. Therefore, it is important to design controllers that are robust with respect to forecast errors and errors in the determination of their probability distribution.

Although risk-averse problems enjoy favourable properties, their applicability has been limited by their complexity and computational cost of resulting multistage risk-averse optimal control problems. The reason is that their cost function is a composition of several nonsmooth mappings [30]. To date, there have only been slow numerical optimisation methods (e.g., stochastic dual dynamic programming) and limited to linear cost functionals [31], [32]. An alternative solution approach uses multiparametric piecewise quadratic programming [33], yet its applicability is limited to systems with few states and small prediction horizons [34]. This has been daunting and risk-averse problems involving integer variables are considered overly computationally complex for real-time applications.

The study of risk-averse optimisation problems is gaining popularity in power systems applications [35] such as unit commitment [36], scheduling [37], [38] and optimal power flow [39], [40], [41]. In [42], using AVaR, an approach for expansion and operation planning for a hydrothermal system is proposed. A multi-stage formulation for short-term trading with uncertain power from wind turbines and market prices is introduced in [43]. For grid-connected MGs a comparison between a scenario-based risk-averse stochastic and a worst-case optimisation approach is presented in [35].

Despite their increasing popularity, most risk-averse approaches [36], [38], [42], [45] are based on simple formulations which fail to capture how risk propagates in time. Proper multistage formulations lead to intricate optimisation problems where the cost function is expressed as a composition of nonsmooth mappings. This makes them less suitable for MPC [28], where fast computations are required. Therefore, in this paper we use a reformulation that decomposes these nested mappings and allows to solve risk-averse MPC problems online.

C. Contributions

In brief, the contributions of this work are: (i) we introduce a novel constrained hybrid dynamical model for islanded MGs, (ii) we propose a multi-stage risk-averse MPC problem for the optimal operation of an MG, (iii) we reformulate the risk-averse optimal control problem in a computationally tractable way and (iv) we demonstrate the properties of the proposed operation control scheme in a simulation case study.

(i) We present the model of an islanded MG with uncertain renewable generation and loads that allows for configurations with very high share of RES. This model, motivated by [10], [20], considers a possible limitation of renewable infeed while limitations on transmission lines are approximately accounted for using DC power flow approximations. We model storage devices as grid-forming units and consider power sharing with the enabled conventional generators. This way, the fluctuations of load and renewable generation affect the power of all units




Fig. 1. Control scheme used in the risk-averse MPC approach for islanded MGs (motivated by [20], [44]).

and the state of charge of the storage devices. This allows to model operating modes where only RES and storage units are used and no conventional unit is required.

(ii) We extend [10], [20] to formulate a risk-averse MPC problem for islanded MGs. Unlike risk-neutral stochastic MPC [20], [44], where a large number of scenarios is needed for an accurate representation of the distributions, risk-averse MPC allows for fewer scenarios as it mitigates the effect of uncertainty in the estimated probability distribution. This allows for robustness against bad forecast models of load and renewable infeed, time-varying probability distributions, or approximation errors in the scenario tree generation. Risk-averse formulations allow to interpolate between worst-case [10] and stochastic [20] MPC to specify the acceptable level of risk and provide resilience against high-effect low-probability events.

(iii) Motivated by [28], we use an epigraphical relaxation to reformulate the original risk-averse problem as a mixed-integer quadratically-constrained quadratic problem (MIQCQP). This way we decompose the original nested formulation and render the problem formulation suitable for real-time applications.

(iv) In a comprehensive case study, we demonstrate the use of the proposed risk-averse MPC scheme for a simple MG. We juxtapose the operation of the MG using a stochastic, a worst-case and a risk-averse formulation to show that the conservativeness of the controller can be tuned. Lastly, the robustness with respect to uncertainties in the probability distribution of load and RES is investigated by means of a sensitivity analysis.

D. Structure of paper

The remainder of the paper is structured along the lines of Figure 1. In Section II the model of an islanded MG is introduced. Then, scenario trees are derived from time-series based forecasts in Section III. In Section IV we quantify the operating costs of the MG. Subsequently, risk measures are discussed in Section V and a risk-averse MPC approach is derived in Section VI. Finally, in Section VII, the properties of the resulting MPC are illustrated in a numerical case study.

E. Notation

Real and natural numbers are denoted by \mathbb{R} and \mathbb{N} , respectively. The set of nonnegative integers is denoted by \mathbb{N}_0 . The set $\{x | x \in \mathbb{N}_0 \wedge a \leq x \leq b\}$ is denoted by $\mathbb{N}_{[a,b]}$. Furthermore, the set of nonnegative real numbers is $\mathbb{R}_{\geq 0}$ and the set of positive real numbers is $\mathbb{R}_{> 0}$. The cardinality of a set \mathbb{V} is denoted by $|\mathbb{V}|$. The transpose of a vector a is a^\top . The vector $[a_{v_1} \ a_{v_2} \ \dots \ a_{v_N}]^\top$ composed of elements a_{v_i} for

all $v_i \in \mathbb{V} = \{v_1, v_2, \dots, v_N\} \subset \mathbb{N}$ with $v_i < v_j$ for $i < j$, $i \in \mathbb{N}_{[1,N]}$, $j \in \mathbb{N}_{[1,N]}$ is denoted by $[a_i]_{i \in \mathbb{V}}$. A vector of dimension N whose elements are all equal to 1 is denoted by 1_N . Let $a = [a_1 \ \dots \ a_N]^\top$. Then, $\text{diag}(a)$ denotes the diagonal matrix with entries a_i , $i \in \mathbb{N}_{[1,N]}$.

When used with vectors, the relations $\geq, \leq, <, >$ are understood element-wise. Function $\max(a, b)$ returns the element-wise maximum of the vectors a and b . However, if the function is used with only one vector input argument, i.e., $\max(a)$, then it returns the largest element of the vector a . The same holds for the minimum function $\min(\cdot)$. We denote by $\min_{x \in \mathbb{X}} f(x)$ the minimum value of function f over \mathbb{X} and by $\max_{x \in \mathbb{X}} f(x)$ the maximum value of f over \mathbb{X} .

II. MICROGRID MODEL

In this section, we derive a control-oriented mathematical model of an islanded MG. The model includes loads, conventional, renewable and storage units as well as transmission lines. The example of a basic MG that includes all these components is shown in Fig. 7. The MG model has the form

$$x(k) + Bq(k) - x(k+1) = 0, \quad (1a)$$

$$H_1 \cdot x(k+1) \leq h_1, \quad (1b)$$

$$H_2 \cdot [v(k)^\top \ q(k)^\top \ w(k)^\top]^\top \leq h_2, \quad (1c)$$

$$G \cdot [v(k)^\top \ q(k)^\top \ w(k)^\top]^\top = g, \quad (1d)$$

where $k \in \mathbb{N}_0$ is the discrete time instant. Here, $x(k) \in \mathbb{R}_{\geq 0}^S$ with $S \in \mathbb{N}$ is the state vector and $q(k) \in \mathbb{R}^Q$ is a vector of $Q \in \mathbb{N}$ auxiliary variables. The control inputs are collected in the vector $v(k) = [u(k)^\top \ \delta_t(k)^\top]^\top$, where $u(k) \in \mathbb{R}^U$ is the vector of real-valued control inputs of all $U \in \mathbb{N}$ units and $\delta_t(k) \in \{0, 1\}^T$ the vector of $T \in \mathbb{N}$ Boolean inputs. The uncertain external inputs of the model are collected in the vector $w(k) \in \mathbb{R}^W$, $W \in \mathbb{N}$. In (1a), $B \in \mathbb{R}^{S \times Q}$ and in (1b), H_1, h_1 are of appropriate dimensions. Furthermore, in (1c), H_2 is a matrix and h_2 a vector of appropriate dimensions that reflect inequality constraints. Likewise, in (1d) G is a matrix and g a vector of appropriate dimensions that reflect equality constraints.

In what follows, we will derive a control-oriented MG model of the form (1). We start by posing some assumptions.

Assumption II.1 (Lower control layers). The lower control layers, i.e., primary and secondary control, are designed such that the MG can run autonomously for several minutes, so providing power setpoints to the units on the same timescale is sufficient. These control layers ensure a desired power sharing (see, e.g., [46], [47]) among the grid-forming units.

Assumption II.2 (Conventional units). The startup and shutdown times of the conventional units are small compared to the sampling time of MPC, i.e., switching actions are assumed to be instantaneous. Changes in power are instantaneous, i.e., no climb rates need to be considered.

Assumption II.3 (Storage units). The state of charge can be estimated sufficiently accurately and is accessible to the operation control. The error introduced by neglecting self discharge and conversion losses of storage units is small compared to the uncertainty introduced by renewable infeed and loads.

Assumption II.4 (Transmission lines). The resistance of the transmission lines between the units and loads of the MG as well as the reactive power flow are negligible. The voltage amplitudes in the grid are constant and the phase angle differences small, so the DC power flow approximations [48] can be used. The error introduced hereby is small compared to the uncertainty introduced by renewable infeed and loads.

A. Plant model interface

The real-valued manipulated variables are the power setpoints of the units $u(k) = [u_t(k)^\top u_s(k)^\top u_r(k)^\top]^\top \in \mathbb{R}^U$ where $u_t(k) \in \mathbb{R}_{\geq 0}^T$ are the setpoints of the T conventional units, $u_s(k) \in \mathbb{R}^S$ the setpoints of the S storage units and $u_r(k) \in \mathbb{R}_{\geq 0}^R$ the setpoints of the R RES. Every conventional unit is associated with a Boolean input that indicates whether it is enabled or disabled. All Boolean inputs are collected in a vector $\delta_t(k) \in \{0, 1\}^T$. Furthermore, the stored energies of the storage units are collected in the state vector $x(k) \in \mathbb{R}_{\geq 0}^S$. The uncertain external inputs of the model are $w(k) = [w_r(k)^\top w_d(k)^\top]^\top$, where $w_r(k) \in \mathbb{R}_{\geq 0}^R$ represents the maximum available power of the renewable units under given weather conditions and $w_d(k) \in \mathbb{R}_{\geq 0}^D$ the load.

B. Power of units

In islanded mode, equilibrium of production, consumption and storage power must be ensured in presence of uncertain load and renewable infeed. Therefore, the power of the units $p(k) \in \mathbb{R}^U$ is not necessarily equal to the setpoints $u(k)$. The vector of power values $p(k) = [p_t(k)^\top p_s(k)^\top p_r(k)^\top]^\top$ is composed of the power of conventional units, $p_t(k) \in \mathbb{R}_{\geq 0}^T$, storage units, $p_s(k) \in \mathbb{R}^S$, and RES, $p_r(k) \in \mathbb{R}_{\geq 0}^R$.

1) *RES units*: The power provided by the renewable units, $p_r(k)$, and the corresponding setpoints, $u_r(k)$, are limited by

$$p_r^{\min} \leq p_r(k) \leq p_r^{\max} \quad \text{and} \quad (2a)$$

$$p_r^{\min} \leq u_r(k) \leq p_r^{\max} \quad (2b)$$

with $p_r^{\min} \in \mathbb{R}_{\geq 0}^R$ and $p_r^{\max} \in \mathbb{R}_{\geq 0}^R$.

Additionally, the power infeed $p_{r,i}(k) \in \mathbb{R}_{\geq 0}$ of every renewable unit $i \in \mathbb{N}_{[1,R]}$ can be limited by the power setpoint $u_{r,i}(k) \in \mathbb{R}_{\geq 0}$. However, the power only follows the setpoint if the maximum possible infeed under current weather conditions $w_{r,i}(k) \in \mathbb{R}_{\geq 0}$ is greater than or equal $u_{r,i}(k)$. Using the element-wise min operator, this can be described by

$$p_r(k) = \min(u_r(k), w_r(k)). \quad (3)$$

TABLE I
MODEL-SPECIFIC VARIABLES

Symbol	Explanation	Unit	Size
x	Energy of storage units (state)	pu h	S
u_t	Setpoint inputs of conventional units	pu	T
u_s	Setpoint inputs of storage units	pu	S
u_r	Setpoint inputs of renewable units	pu	R
u	Setpoint inputs of all units	pu	U
δ_t	Boolean inputs of conventional units	—	T
v	Vector of all control inputs	—	Q
w_r	Uncertain available renewable power	pu	R
w_d	Uncertain load	pu	D
w	Vector of all uncertain inputs	pu	W
p_t	Power of conventional units	pu	T
p_s	Power of storage units	pu	S
p_r	Power of renewable units	pu	R
p	Power of all units	pu	U
p_e	Power over transmission lines	pu	E
δ_r	Boolean auxiliary variables	—	R
ρ	Real-valued auxiliary variable	—	1
q	Vector of all auxiliary variables	—	Q

For the formulation of the optimisation problem it is beneficial to transform (3) into a set of linear inequalities involving integer variables. This is done by introducing the free variable $\delta_r(k) \in \{0, 1\}^R$. With the constants $m_r \in \mathbb{R}$, $m_r < \min(p_r^{\min})$ and $M_r \in \mathbb{R}_{\geq 0}$, $M_r > \max(p_r^{\max})$ which are calculated offline, we then exactly reformulate (3) as (see, e.g., [49])

$$p_r(k) \leq u_r(k), \quad (4a)$$

$$p_r(k) \geq u_r(k) + (\text{diag}(w_r(k)) - M_r I_R) \delta_r(k), \quad (4b)$$

$$p_r(k) \leq w_r(k), \quad (4c)$$

$$p_r(k) \geq w_r(k) - (\text{diag}(w_r(k)) - m_r I_R)(1_R - \delta_r(k)). \quad (4d)$$

2) *Conventional units*: The power provided by conventional unit $i \in \mathbb{N}_{[1,T]}$ is limited by $p_{t,i}^{\min} \in \mathbb{R}_{\geq 0}$ and $p_{t,i}^{\max} \in \mathbb{R}_{\geq 0}$ if it is enabled, i.e., if $\delta_{t,i}(k) = 1$. If the unit is disabled, i.e., $\delta_{t,i}(k) = 0$, then naturally $p_{t,i}(k) = 0$. In vector notation and with $p_t^{\min} \in \mathbb{R}_{\geq 0}^T$, $p_t^{\max} \in \mathbb{R}_{\geq 0}^T$ this can be expressed by

$$\text{diag}(p_t^{\min}) \delta_t(k) \leq p_t(k) \leq \text{diag}(p_t^{\max}) \delta_t(k). \quad (5a)$$

The same holds for the power setpoints, i.e.,

$$\text{diag}(p_t^{\min}) \delta_t(k) \leq u_t(k) \leq \text{diag}(p_t^{\max}) \delta_t(k). \quad (5b)$$

3) *Storage units*: As the storage units are assumed to be always enabled, all their setpoints and power values are limited by $p_s^{\min} \in \mathbb{R}_{\geq 0}^S$ and $p_s^{\max} \in \mathbb{R}_{\geq 0}^S$, i.e.,

$$p_s^{\min} \leq p_s(k) \leq p_s^{\max}, \quad (6a)$$

$$p_s^{\min} \leq u_s(k) \leq p_s^{\max}. \quad (6b)$$

C. Power sharing of grid-forming units

Due to variations of load and renewable infeed, the power of all units does not necessarily match the power setpoints that are prescribed to the system. The grid-forming units, i.e., all storage and conventional units, are assumed to be controlled by the lower control layers such that they share the changes in load and renewable infeed in a desired proportional manner. This so called proportional power sharing (see, e.g., [46], [47])

depends on the design parameter $\chi_i \in \mathbb{R}_{>0}$ for all grid-forming units. A typical choice of χ_i is, e.g., proportional to the nominal power of the corresponding units.

Power sharing can be formalised as follows. Two units $i \in \mathbb{N}_{[1, T+S]}$ and $j \in \mathbb{N}_{[1, T+S]}$, $i \neq j$ with $\chi_i \in \mathbb{R}_{>0}$ and $\chi_j \in \mathbb{R}_{>0}$ are said to share their power proportionally, if

$$\frac{p_i(k) - u_i(k)}{\chi_i} = \frac{p_j(k) - u_j(k)}{\chi_j} \quad (7)$$

holds. Using the auxiliary free variable $\rho(k) \in \mathbb{R}$ and including that only enabled units, i.e., units i with $\delta_{t,i}(k) = 1$, can participate in power sharing, we can rewrite (7) for all grid-forming units with $K_t = \text{diag}([1/\chi_1 \cdots 1/\chi_T]^\top)$ and $K_s = \text{diag}([1/\chi_{(T+1)} \cdots 1/\chi_{(T+S)}]^\top)$ as

$$K_t(p_t(k) - u_t(k)) = \rho(k)\delta_t(k) \text{ and} \quad (8a)$$

$$K_s(p_s(k) - u_s(k)) = \rho(k)1_S. \quad (8b)$$

To proceed with what follows in the next sections, we need to transform (8a) into a set of linear inequalities with integer variables. This can be done using a similar strategy as described in [49]. First, we choose $M_t \in \mathbb{R}$ which can be calculated offline. The value of M_t should be greater than the biggest possible value of $\rho(k)$. Hence, with the biggest possible value for the storage units, $\rho_s^{\max} = \max(K_s(p_s^{\max} - p_s^{\min}))$, and for the conventional units, $\rho_t^{\max} = \max(K_t(p_t^{\max} - p_t^{\min}))$, M_t has to be chosen such that $\max(\rho_s^{\max}, \rho_t^{\max}) < M_t$. Then, with $m_t = -M_t$, we can exactly reformulate (8a) as

$$K_t(p_t(k) - u_t(k)) \leq M_t\delta_t(k), \quad (9a)$$

$$K_t(p_t(k) - u_t(k)) \geq m_t\delta_t(k), \quad (9b)$$

$$K_t(p_t(k) - u_t(k)) \leq 1_T\rho(k) - m_t(1_T - \delta_t(k)), \quad (9c)$$

$$K_t(p_t(k) - u_t(k)) \geq 1_T\rho(k) - M_t(1_T - \delta_t(k)). \quad (9d)$$

D. Dynamics of storage units

The dynamics of all storage units are assumed as

$$x(k+1) = x(k) - T_s p_s(k), \quad (10a)$$

where $T_s \in \mathbb{R}_{>0}$ is the sampling time. The stored energy is represented by $x(k)$ with initial state $x(0) = x_0$. To cover for the limited storage capacity, $x(k+1)$ is bounded by

$$x^{\min} \leq x(k+1) \leq x^{\max}, \quad (10b)$$

with $x^{\min} = 0_S$ and $x^{\max} \in \mathbb{R}_{\geq 0}^S$.

Remark II.5. In the simulations in Section VII, we use a more detailed plant model that is different from (10a). This storage model is motivated by [7] and includes self-discharge as well as charging and discharging efficiencies. It reads

$$x(k+1) = \begin{cases} x(k) - T_s \eta^c p_s(k) - x^{\text{sd}}, & \text{if } p_s(k) \leq 0, \\ x(k) - T_s (\eta^d)^{-1} p_s(k) - x^{\text{sd}}, & \text{if } p_s(k) > 0. \end{cases} \quad (11)$$

Here, $\eta^c \in (0, 1]^{S \times S}$ is the diagonal matrix of charging efficiencies of the units and $\eta^d \in (0, 1]^{S \times S}$ the diagonal matrix of discharging efficiencies, both with nonzero diagonal elements. Furthermore, $x^{\text{sd}} \in \mathbb{R}_{\geq 0}^S$ models self-discharge.

The simplified storage dynamics of the control-oriented model (10a) can be derived from (11) by assuming that $\eta^c = \eta^d = \text{diag}(1_S)$ and that $x^{\text{sd}} = 0_S$. Note that (10a) is used in an MPC context where the state is sampled at every time instant and used as initial value to predict future states. Such a strategy allows to use of less accurate models due to its inherent robustness [50]. Furthermore, the error introduced by uncertain renewable infeed and load is assumed to be much larger than the one introduced by (10a) (see Assumption II.3). Therefore, the simplification is of minor importance.

E. Transmission network

The power transmitted over the lines can be derived using DC power flow approximations for AC grids [10], [48]. Thus, the power flowing over the E transmission lines, $p_e(k) = [p_{e,1}(k) \cdots p_{e,E}(k)]^\top$, can be derived from the power of the units and the load using the linear relation

$$p_e(k) = F \cdot [p(k)^\top \quad w_d(k)^\top]^\top, \quad (12a)$$

where $F \in \mathbb{R}^{E \times (U+D)}$ is a matrix that links the power flowing over the lines with the power provided or consumed by the units and loads. More information on the derivation of F can be found, e.g., in [10], [51]. Due to the limited transmission capability of the lines, $p_e(k)$ is desired to be bounded by

$$p_e^{\min} \leq p_e(k) \leq p_e^{\max} \quad (12b)$$

with $p_e^{\min} \in \mathbb{R}_{\leq 0}^E$ and $p_e^{\max} \in \mathbb{R}_{\geq 0}^E$. Additionally, the generated power must equal consumed power at all times, i.e.,

$$1_T^\top p_t(k) + 1_S^\top p_s(k) + 1_R^\top p_r(k) = 1_D^\top w_d(k). \quad (12c)$$

Remark II.6. There are small MGs in which all units are directly connected to a single bus, e.g., in [7], [22]. Such MGs can be modelled in two ways with (12). (i) Discard constraints (12a) and (12b) and only keep (12c). (ii) Set $F = [1_U^\top \quad -1_D^\top]$. Due to (12c), in this case $p_e(k) = 0$ holds for all $k \in \mathbb{N}_0$ and the limits can be chosen as $p_e^{\min} = p_e^{\max} = 0$.

Remark II.7. For the plant simulation model in Section VII, we use the nonlinear power flow equations [52], [47]. Thus, the power provided or consumed by unit or load $i \in \mathbb{N}_{[1, J]}$, where $J = U + D$ is the total number of units and loads, is

$$p_{e,i}(k) = \hat{v}_i \sum_{\substack{j=1 \\ j \neq i}}^J \hat{v}_j g_{ij} - \hat{v}_j (g_{ij} \cos(\theta_{ij}(k)) + b_{ij} \sin(\theta_{ij}(k))), \quad (13)$$

Here, $\hat{v}_i \in \mathbb{R}_{>0}$ is the voltage amplitude at node i and $\theta_{ij}(k) = \theta_i(k) - \theta_j(k)$ is the difference between the phase angles $\theta_i(k) \in \mathbb{R}$ at node i and $\theta_j(k) \in \mathbb{R}$ at node $j \in \mathbb{N}_{[1, J]}$. Furthermore, $g_{ij} \in \mathbb{R}_{\geq 0}$ is the conductance and $b_{ij} \in \mathbb{R}$ the susceptance of the line connecting nodes i and j .

Note that (12a) can be derived from (13) using Assumption II.4, i.e., assuming inductive lines with $g_{ij} = 0$, constant voltage amplitudes \hat{v}_i and small angle differences $\theta_{ij}(k)$ such that $\sin(\theta_{ij}(k)) \approx \theta_{ij}(k)$ can be used for all $i, j \in \mathbb{N}_{[1, J]}$. With these assumptions and with $\tilde{b}_{ij} = -\hat{v}_i \hat{v}_j b_{ij}$, (13) becomes

$$p_{e,i}(k) = \sum_{\substack{j=1 \\ j \neq i}}^J \tilde{b}_{ij} \theta_{ij}(k). \quad (14)$$




Fig. 2. Wind and load power forecast with seasonal ARIMA models from [20] over a horizon of 4 h. The collection of independent forecast scenarios was generated using Monte Carlo simulations with 500 seeds. The maximum number of children per node was chosen as 8 for the root node, 2 for the nodes of stage 1 and 1 for all other stages.

This equation can now be used to derive matrix F in (12a) (see, e.g., [12]). Although more accurate convex power flow models exist (see, e.g., [53]), we assume that the error introduced by uncertain renewable infeed and load is much larger than the one introduced by (12a) (see Assumption II.4).

F. Overall model

Having discussed the different components of the islanded MG, we can now derive the a control-oriented model of the form (1) based on (2), (4)–(6), (8b)–(12). Here, the auxiliary vector is $q(k) = [p(k)^\top \delta_r(k)^\top \rho(k)^\top]^\top$. Moreover, $B = [0_{S \times T} \quad -T_s I_S \quad 0_{S \times 2R+1}]$, $H_1 = \text{diag}([1_S^\top \quad -1_S^\top]^\top)$ and $h_1 = [(x^{\max})^\top \quad (-x^{\min})^\top]^\top$. Furthermore, H_2 and h_2 in (1c) are formed such that they reflect (2), (4)–(6), (9) and (12b). Additionally, G and g in (1d) are formed such that they reflect (8b), (12a) and (12c).

III. UNCERTAINTY MODEL

This section focuses on the representation of uncertain load and renewable infeed. First the generation of a collection of forecast scenarios is discussed. Then scenario-trees are illustrated and the model of an MG with uncertain load and renewable generation is derived.

A. Representation of uncertainty by collections of scenarios

To obtain a representative probability distribution of load and renewable infeed for the controller, a sampling based Monte Carlo forecast was chosen. Here, random samples that follow the error distribution obtained from the training of the forecast model are drawn and applied to the forecast to generate a collection of independent scenarios where every scenario has the same probability. Thus, for a high number of independent forecast scenarios the probability distribution of the forecast is approximated. To generate scenarios of load and available renewable power, the seasonal ARIMA models from [20] were used (see Figure 2). For more information on time-series based forecasting, the reader is referred to [54].




Fig. 3. Probability tree with $N = 2$ and $\mu = 6$ nodes. The nodes of the stages are $\text{nodes}(0) = \{0\}$ as well as $\text{nodes}(1) = \{1, 2\}$ and $\text{nodes}(2) = \{3, 4, 5\}$. Note that $\text{anc}(1) = 0$, $\text{anc}(3) = 1$ and $\text{anc}(5) = 2$. Also $\text{child}(0) = \{1, 2\}$, $\text{child}(1) = \{3, 4\}$ and $\text{child}(2) = \{5\}$. The scenarios of the tree are the sequences $(0, 1, 3)$, $(0, 1, 4)$ and $(0, 2, 5)$.

To achieve a sufficiently accurate approximation of the forecast probability distribution, a high number of independent forecast scenarios is desired. This leads to an undesired high computational complexity in finding a suitable control action as a high number of scenarios often leads to a high number of decision variables. To satisfy both needs sufficiently, we generate scenario trees which serve as a more compact representation of the probability distribution.

B. From data to scenario trees

Scenario trees can be constructed from collections of forecast scenarios. They can be obtained using methodologies such as [55] or scenario reduction (see, e.g., [26], [27]). There exist several other scenario generation algorithms, e.g., clustering-based [56], [57] as well as simulation and optimisation-based approaches [58], [59]. An example of such a collection of independent forecast scenarios and the corresponding scenario tree for a forecast of load and available wind power is shown in Figure 2 on the right. This tree was generated using fast forward selection as described by [60, Algorithm 5] which is a modification of [26, Algorithm 2.4].

C. Representation of uncertainty using scenario trees

A scenario tree is a representation of the uncertain evolution of a discrete-time finite-valued random process as illustrated in Figure 3. A tree is a collection of $\mu \in \mathbb{N}$ nodes partitioned into stages $j \in \mathbb{N}_{[0, N]}$ and indexed with a unique identifier $i \in \mathbb{N}_{[0, \mu-1]}$. Each node is associated with a possible value of the state of the process at a future time instant starting from an initial node $i = 0$ at stage $j = 0$ which is called the root node of the tree. The set of nodes at stage j is denoted by $\text{nodes}(j) \subseteq \mathbb{N}_{[0, \mu-1]}$. Conversely, the stage in which a node i resides is denoted by $\text{stage}(i) \in \mathbb{N}_{[0, N]}$. The nodes at stage $j = N$ are called leaf nodes. All non-leaf nodes i at a stage j possess a set of child nodes which are in stage $j + 1$ and are connected to i ; these are denoted by $\text{child}(i) \subseteq \text{nodes}(j+1)$. Likewise, every node $i \neq 0$ is reachable from a single ancestor node, which resides in the previous stage and is denoted by $\text{anc}(i) \in \text{nodes}(\text{stage}(i) - 1)$. A scenario is a sequence of nodes (s_0, \dots, s_N) such that $s_N \in \text{nodes}(N)$ and $\text{anc}(s_a) = s_{a-1}$, $a \in \mathbb{N}_{[1, N]}$. Scenarios are uniquely identified by leaf




Fig. 4. Relation of optimisation variables on scenario tree for power (left) and energy (right). Note that the power values are piecewise constant. The power setpoints $v^{(0)}$ are represented by the green line, the uncertain inputs $w^{(1)}, w^{(2)}$ by blue lines and the auxiliary variables $q^{(1)}, q^{(2)}$ by black lines. Functions f_q and f_x are given implicitly via (1).

nodes. The probability of visiting node $i \in \mathbb{N}_{[0, \mu-1]}$ is denoted by $\pi^{(i)} > 0$. That said, at stage j , the set **nodes**(j) is a probability space with $\sum_{i \in \text{nodes}(j)} \pi^{(i)} = 1$.

For the tree shown in Figure 3, the relation of the different variables at $j = 0$ and $j = 1$ is illustrated in Figure 4. As shown here, we make a decision $v^{(0)}$ at stage $j = 0$ without knowing which disturbance $w^{(1)}$ or $w^{(2)}$ will occur during the time between $j = 0$ and $j = 1$. Depending on the disturbance w , different values of the auxiliary vector q will occur. These can be calculated using the function $f_q(\cdot, \cdot)$ derived from (1). Thus, the choice of $v^{(0)}$ accounts for $q^{(1)} = f_q(v^{(0)}, w^{(1)})$ and $q^{(2)} = f_q(v^{(0)}, w^{(2)})$ without knowing which one occurs. Similarly, following (1a) the state x at time instant $j = 1$ is a function $f_x(\cdot, \cdot)$ of the state at time instant $j = 0$ and the auxiliary vector that is present between $j = 0$ and $j = 1$. Consequently, different values $q^{(1)}$ and $q^{(2)}$ lead to different states $x^{(1)} = f_x(x^{(0)}, q^{(1)}) = f_x(x^{(0)}, f_q(v^{(0)}, w^{(1)}))$ and $x^{(2)} = f_x(x^{(0)}, q^{(2)}) = f_x(x^{(0)}, f_q(v^{(0)}, w^{(2)}))$.

In summary, given an initial measured system state $x^{(0)}$ at stage $j = 0$ and a forecast in the form of $w^{(1)}$ or $w^{(2)}$ we make a decision $v^{(0)}$ using this information. Similarly, at every stage $j \in \mathbb{N}_{[0, N-1]}$, we make decisions $v^{(i)}$, $i \in \text{nodes}(j)$, using the information that is available up to that stage and using the forecast values $w^{(i+)}$ for $i_+ \in \text{child}(i)$. In other words, v is decided using causal control laws. This is indicated in Figure 3 by the positioning of $v^{(i)}$ at the nodes of the tree instead of at its edges. Thus, across the nodes of the scenario trees, the control-oriented model (1) for all nodes $i_+ \in \mathbb{N}_{[1, \mu-1]}$ with $i = \text{anc}(i_+)$ become

$$x^{(i)} + Bq^{(i_+)} - x^{(i_+)} = 0, \quad (15a)$$

$$H_1 \cdot x^{(i_+)} \leq h_1, \quad (15b)$$

$$H_2 \cdot [v^{(i)\top} \quad q^{(i_+)\top} \quad w^{(i_+)\top}]^\top \leq h_2, \quad (15c)$$

$$G \cdot [v^{(i)\top} \quad q^{(i_+)\top} \quad w^{(i_+)\top}]^\top = g. \quad (15d)$$

IV. OPERATING COSTS

In this section we derive an operating cost function for an MG which reflects the main objectives: (i) economic operation, (ii) low number of switching actions, (iii) high use of RES and (iv) desired state of storage units. We use cost functions that are motivated by [20]. Our presentation will hinge on the scenario tree structure introduced in Section III-C, i.e., objectives will be defined at the nodes of a scenario tree.

The objective at node $i_+ \in \mathbb{N}_{[1, \mu-1]}$ with $i = \text{anc}(i_+)$ and $i_- = \text{anc}(i)$ is composed of $\ell_o(v^{(i)}, v^{(i_-)}, q^{(i_+)}) \in \mathbb{R}_{\geq 0}$ that reflects items (i)–(iii), and $\ell_s(x^{(i_+)}) \in \mathbb{R}_{\geq 0}$ that reflects (iv). A discount factor $\gamma \in (0, 1)$ is used to emphasise decisions in the near future. Thus, the cost associated with node i_+ is

$$\ell(x^{(i_+)}, v^{(i)}, v^{(i_-)}, q^{(i_+)}) = \gamma^{\text{stage}(i_+)} (\ell_o(v^{(i)}, v^{(i_-)}, q^{(i_+)}) + \ell_s(x^{(i_+)})). \quad (16)$$

Remark IV.1. Note that the cost associated with node i_+ , $\ell_o(v^{(i)}, v^{(i_-)}, q^{(i_+)})$, also depends on nodes $i = \text{anc}(i_+)$ and $i_- = \text{anc}(i)$. The reason for this is that $q^{(i_+)}$ is a function of the input $v^{(i)}$ (see Section III-C). Therefore, it is required to use $q^{(i_+)}$ and $v^{(i)}$ with $i = \text{anc}(i_+)$ in the same cost function. As the cost that is caused by $v^{(i)}$ partly depends on the input at the past time instant, e.g., in case of switching penalties, it is further required to include $v^{(i_-)}$.

The economically motivated cost includes (i) operating costs of conventional units, $\ell_t^{\text{rt}}(v^{(i)}, q^{(i_+)}) \in \mathbb{R}_{\geq 0}$, (ii) costs for switching conventional units on or off, $\ell_t^{\text{sw}}(v^{(i)}, v^{(i_-)}) \in \mathbb{R}_{\geq 0}$, and (iii) costs incurred by low utilisation of renewable sources, $\ell_r(q^{(i_+)}) \in \mathbb{R}_{\geq 0}$, i.e.,

$$\ell_o(v^{(i)}, v^{(i_-)}, q^{(i_+)}) = \ell_t^{\text{rt}}(v^{(i)}, q^{(i_+)}) + \ell_t^{\text{sw}}(v^{(i)}, v^{(i_-)}) + \ell_r(q^{(i_+)}). \quad (17)$$

More precisely, following [61], the operating cost of the conventional units is modelled as

$$\ell_t^{\text{rt}}(v^{(i)}, q^{(i_+)}) = c_t^\top \delta_t^{(i)} + c_t'^\top p_t^{(i_+)} + \|\text{diag}(c_t'') p_t^{(i_+)}\|_2^2, \quad (18a)$$

with weights $c_t \in \mathbb{R}_{>0}^T$, $c_t' \in \mathbb{R}_{>0}^T$ and $c_t'' \in \mathbb{R}_{>0}^T$ and using the square of the Euclidean norm $\|\cdot\|_2^2$.

Costs for switching the conventional units on or off from node $i_- = \text{anc}(i)$ to node i are modelled by

$$\ell_t^{\text{sw}}(v^{(i)}, v^{(i_-)}) = \|\text{diag}(c_t^{\text{sw}}) (\delta_t^{(i_-)} - \delta_t^{(i)})\|_2^2 \quad (18b)$$

with weight $c_t^{\text{sw}} \in \mathbb{R}_{>0}^T$. For the root node, $\delta_t^{(0)}$ denotes the initial switch state of the conventional units, $\delta_{t,k-1}$.

It is desired to maximise renewable infeed. This can be included in the stage cost as a penalty if the renewable infeed is less than the nominal value p_r^{max} , i.e., with $c_r \in \mathbb{R}_{>0}^R$,

$$\ell_r(q^{(i_+)}) = \|\text{diag}(c_r) (p_r^{\text{max}} - p_r^{(i_+)})\|_2^2. \quad (18c)$$

Very high or very low values of $x(k)$, can increase the ageing of batteries [62]. To reduce the occurrence of such values, we introduce the interval of desired values of $x(k)$, $[\tilde{x}^{\min}, \tilde{x}^{\max}] \subseteq [x^{\min}, x^{\max}]$. To enforce $x(k) \in [\tilde{x}^{\min}, \tilde{x}^{\max}]$ we define $\ell_s(x^{(i)})$ with $c_s \in \mathbb{R}_{>0}^S$ as

$$\ell_s(x^{(i)}) = c_s^\top (\max(\tilde{x}^{\min} - x^{(i)}, 0_S) - \min(\tilde{x}^{\max} - x^{(i)}, 0_S)). \quad (19)$$

For every node $i_+ \in \mathbb{N}_{[1, \mu-1]}$ with $i_+ \in \text{child}(i)$ as well as $i_- = \text{anc}(i)$ we define the cost variable

$$Z^{(i_+)} = \ell(x^{(i_+)}, v^{(i)}, v^{(i_-)}, q^{(i_+)}). \quad (20a)$$

Thus, for stage $j \in \mathbb{N}_{[1, N]}$, the vector

$$Z_j = [Z^{(i_+)}]_{i_+ \in \text{nodes}(j)} \quad (20b)$$

is associated with a random variable on the probability space $\mathbf{nodes}(j)$. Note that $Z_j \in \mathbb{R}^{|\mathbf{nodes}(j)|}$ is a function of states $x^{(i_+)}$, inputs $v^{(i_-)}$ and auxiliary variables $q^{(i_+)}$ for all $i_+ \in \mathbf{nodes}(j)$, $i_- = \mathbf{anc}(i_+)$ and $i_- = \mathbf{anc}(i_-)$. Using (20b), we can describe the multi-stage cost by the sequence (Z_1, \dots, Z_N) .

V. MEASURING RISK

In this section we introduce the notion of risk measures and provide a few examples thereof. Furthermore, we will discuss one specific risk measure: the average value-at-risk (AVaR).

A. Introduction to risk measures

Let $\Omega = \{\omega_1, \dots, \omega_K\}$ be a sample space, whose elements ω_i have probabilities $\pi_i > 0$ for $i \in \mathbb{N}_{[1,K]}$. The probabilities can be collected in a vector $\pi = [\pi_1 \dots \pi_K]^\top$. This vector is an element of the probability simplex, i.e., the set $\mathbb{D} = \{\pi \in \mathbb{R}^K \mid \pi_i \geq 0, \sum_{i=1}^K \pi_i = 1\}$. A random variable on Ω is a function $\bar{Z} : \Omega \rightarrow \mathbb{R}$ with $\bar{Z}(\omega_i) = Z_i$. All values of \bar{Z} can be collected in a vector $Z = [Z_1 \dots Z_K]^\top \in \mathbb{R}^K$. Note that in our case, these values are given by (20) and represent the operation cost at the nodes of the scenario tree.

A risk measure on Ω is a mapping $\rho : \mathbb{R}^K \rightarrow \mathbb{R}$ that, roughly speaking, quantifies the significance of extreme events. A well-known, yet trivial, risk measure is the expectation operator $\mathbf{E}_\pi(Z) = \sum_{i=1}^K \pi_i Z_i$, which is often referred to as a risk-neutral measure as it carries no deviation information. Another example of a risk measure is the maximum operator $\max(Z) = \max\{Z_i \mid i=1, \dots, K\}$ which quantifies the worst-case value, or realisation, of Z . It can be written as

$$\max(Z) = \max_{\pi' \in \mathbb{D}} \mathbf{E}_{\pi'}(Z), \quad (21)$$

where the maximum is taken with respect to all probability vectors $\pi' \in \mathbb{D}$. Therefore, it can be interpreted as the worst-case expectation over all possible probability distributions. Following the notation in (21), the expectation operator is

$$\mathbf{E}_\pi(Z) = \max_{\pi' \in \{\pi\}} \mathbf{E}_{\pi'}(Z), \quad (22)$$

In this work we focus on coherent¹ risk measures as they quantify risk in a natural and intuitive way. Also, they allow for a computationally tractable reformulation of risk-averse problems which renders them suitable for MPC applications.

It is shown in [30, Thm. 6.5] that all coherent risk measures can be written in a form reminiscent of (21) and (22) as

$$\rho(Z) = \max_{\pi' \in \mathbb{A}} \mathbf{E}_{\pi'}(Z), \quad (23)$$

where $\mathbb{A} \subseteq \mathbb{D}$ is a closed convex set which contains π . Every mapping of the form (23), where the so-called ambiguity set \mathbb{A} of ρ is a closed convex set which contains π , is coherent.

¹Let \bar{Z}, \bar{Z}' be two random variables on Ω and Z, Z' the corresponding vectors. Then, $\rho : \mathbb{R}^K \rightarrow \mathbb{R}$ is a coherent risk measure (see [30, Def. 6.4.]) if it is (i) convex, i.e., $\rho(\lambda Z + (1-\lambda)Z') \leq \lambda \rho(Z) + (1-\lambda)\rho(Z')$ for all $\lambda \in [0, 1]$, (ii) monotone, i.e., $\rho(Z) \leq \rho(Z')$ whenever $Z \leq Z'$, (iii) translation equi-variant, i.e., $\rho(c1_K + Z) = c + \rho(Z)$ for all $c \in \mathbb{R}$, and (iv) positive homogeneous, i.e., $\rho(\alpha Z) = \alpha \rho(Z)$ for all $\alpha \in \mathbb{R}_{\geq 0}$.




Fig. 5. Ambiguity sets \mathbb{A}_α over a probability space with $K = 3$ and $\pi = [0.3 \ 0.3 \ 0.4]^\top$. The ambiguity set \mathbb{A}_0 is the whole probability simplex, and \mathbb{A}_1 the point $\{\pi\}$. Naturally, $\mathbb{A}_{\alpha_1} \subseteq \mathbb{A}_{\alpha_2}$ for $\alpha_1 \geq \alpha_2$.

One interpretation of (23) is that we take the worst-case expectation of Z with respect to $\pi' \in \mathbb{A}$, that is, with respect to an inexact known distribution [63]. The expectation and maximum operators are two extreme cases of coherent risk measures. The ambiguity set of $\max(Z)$ is the largest possible set, i.e., $\mathbb{A} = \mathbb{D}$. The ambiguity set of $\mathbf{E}(Z)$ is the smallest possible set, i.e., $\mathbb{A} = \{\pi\}$. Other risk measures can be constructed by taking ambiguity sets of intermediate size to cope with uncertain knowledge of a probability distribution.

Risk measures, whose ambiguity set is a polytope, are called polytopic. Given the extreme points of the ambiguity set, its vertices π_1, \dots, π_L , they assume the convenient representation

$$\rho(Z) = \max_{l \in \mathbb{N}_{[1,L]}} \mathbf{E}_{\pi_l}(Z). \quad (24)$$

B. Average value-at-risk

A commonly used risk measure is the average value-at-risk, which is given in the form of (23) as

$$\rho(Z) = \text{AV@R}_\alpha(Z) = \max_{\pi' \in \mathbb{A}_\alpha} \mathbf{E}_{\pi'}(Z) \quad (25a)$$

with the ambiguity set

$$\mathbb{A}_\alpha = \begin{cases} \{\pi' \in \mathbb{D} \mid \pi' \leq \frac{1}{\alpha} \pi\}, & \text{if } \alpha \in (0, 1], \\ \mathbb{D}, & \text{if } \alpha = 0. \end{cases} \quad (25b)$$

for $\alpha \in \mathbb{R}_{[0,1]}$. Clearly, AVaR is a polytopic risk measure since \mathbb{A}_α is a polytope. As shown in Figure 5, \mathbb{A}_α can be modified by varying α . This includes the extreme cases $\alpha = 1$, where $\mathbb{A}_1 = \{\pi\}$ and $\alpha = 0$, where $\mathbb{A}_0 = \mathbb{D}$. Using convex duality arguments and the additional free variable $t \in \mathbb{R}$, (25) can be transformed into [30, Ex. 6.19]

$$\text{AV@R}_\alpha(Z) = \begin{cases} \min(t + \mathbf{E}_\pi(\max(\frac{Z-t1_K}{\alpha}, 0_K))), & \text{for } \alpha \in (0, 1] \\ \max(Z), & \text{for } \alpha = 0. \end{cases} \quad (26)$$

We will now give an equivalent representation of the average value-at-risk which will be useful in Section VI-C as it will facilitate the solution of risk-averse optimal control problems.

Proposition V.1. The average value-at-risk at level $\alpha \in [0, 1]$ is given by

$$\text{AV@R}_\alpha(Z) = \min_{\substack{\xi \geq 0_K \\ \alpha \xi \geq Z - t1_K}} (t + \mathbf{E}_\pi(\xi)). \quad (27)$$

Proof. Let $\alpha \in (0, 1]$. Using the epigraphical relaxation (see [64, Sec. 3.1.7 & 4.1]) of $\max(\cdot, 0)$, we have that

$$\max(y, 0_K) = \min_{\substack{\xi \geq 0_K \\ \xi \geq y}} \xi, \quad (28)$$

for all $y \in \mathbb{R}^K$, where $\xi \in \mathbb{R}^K$ is a slack variable. Therefore,

$$\begin{aligned} \text{AV@R}_\alpha(Z) &= \min \left(t + \mathbf{E}_\pi \left(\max \left(\frac{Z - t1_K}{\alpha}, 0_K \right) \right) \right) \\ &= \min \left(t + \mathbf{E}_\pi \left(\min_{\substack{\xi \geq 0_K \\ \xi \geq \frac{Z - t1_K}{\alpha}}} \xi \right) \right) \\ &= \min \left(t + \mathbf{E}_\pi \left(\min_{\substack{\xi \geq 0_K \\ \alpha \xi \geq Z - t1_K}} \xi \right) \right), \end{aligned}$$

where the second equation is by virtue of (28). Using [30, Prop. 6.60], we interchange the expectation operator, \mathbf{E}_π and the minimum to arrive at (27).

The right hand side of (27) is well defined for $\alpha = 0$, i.e.,

$$\begin{aligned} \text{AV@R}_0(Z) &= \min_{\substack{\xi \geq 0_K \\ t1_K \geq Z}} (t + \mathbf{E}_\pi(\xi)) \\ &= \min_{t1_K \geq Z} t + \min_{\xi \geq 0_K} \mathbf{E}_\pi(\xi) = \min_{t1_K \geq Z} t = \max(Z). \end{aligned}$$

Therefore, (27) holds for all $\alpha \in [0, 1]$. \square

Having discussed risk measures, we will now use them to construct multistage risk-averse MPC problems.

VI. RISK-AVERSE MPC

In this section we will first introduce conditional risk mappings on scenario trees. Then we will construct multistage risk-averse MPC problems and reformulate them as MIQCQPs.

A. Conditional risk mappings on scenario trees

A conditional risk mapping on a scenario tree is a generalisation of the notion of conditional expectation which is the expectation of a random cost Z_{j+1} at stage $j+1$ given all information we can surmise up to stage j . Roughly speaking, a conditional risk mapping at a non-leaf node i of the tree returns the risk of the cost of the children of i . Conditional risk mappings can be constructed as follows.

For every stage $j \in \mathbb{N}_{[0, N-1]}$, the set $\mathbf{nodes}(j)$ is a probability space whose elements $i \in \mathbf{nodes}(j)$ have probability $\pi^{(i)}$. Naturally, we can define real-valued random variables with corresponding vectors $Z_j \in \mathbb{R}^{|\mathbf{nodes}(j)|}$ on that space. Likewise, the set $\mathbf{nodes}(j+1)$ is also a probability space. A conditional risk mapping at stage j is a mapping

$$\rho_j : \mathbb{R}^{|\mathbf{nodes}(j+1)|} \rightarrow \mathbb{R}^{|\mathbf{nodes}(j)|}, \quad (29)$$

which is constructed as we explain hereafter.

For all $i \in \mathbf{nodes}(j)$, the sets $\mathbf{child}(i) \subseteq \mathbf{nodes}(j+1)$ are disjoint and define a partition over $\mathbf{nodes}(j+1)$, i.e., $\mathbf{nodes}(j+1) = \bigcup_{i \in \mathbf{nodes}(j)} \mathbf{child}(i)$. Given that node i is visited, $i_+ \in \mathbf{child}(i)$ occurs with probability $\pi^{(i_+)}/\pi^{(i)}$. This makes $\mathbf{child}(i)$ into a probability space whereon we can construct random variables with vectors $Z^{[i]} = [Z^{(i_+)}]_{i_+ \in \mathbf{child}(i)}$. In particular, Z_{j+1} on the probability space $\mathbf{nodes}(j+1)$ is decomposed into vectors $Z^{[i]}$ on $\mathbf{child}(i)$, $i \in \mathbf{nodes}(j)$.




Fig. 6. Example of conditional risk mapping conditioned at stage $j = 1$. Following (29), ρ_1 is a conditional risk mapping $\rho_1 : \mathbb{R}^5 \rightarrow \mathbb{R}^2$. Note here that $Z_2 = [Z^{(3)} \dots Z^{(7)}]^\top$, is decomposed into $Z^{[1]}$ and $Z^{[2]}$.

Using a coherent risk measure $\rho^{(i)} : \mathbb{R}^{|\mathbf{child}(i)|} \rightarrow \mathbb{R}$, we can compute a risk $\rho^{(i)}(Z^{[i]})$ for every vector $Z^{[i]}$. Thus, we define the conditional risk mapping ρ_j at stage j as

$$\rho_j(Z_{j+1}) = [\rho^{(i)}(Z^{[i]})]_{i \in \mathbf{nodes}(j)}. \quad (30)$$

In words, ρ_j maps the probability distribution at stage $j+1$ into a vector whose i th element denotes the risk that will incur if one is at node $i \in \mathbf{nodes}(j)$. For a simple scenario tree, this is illustrated in Figure 6.

Remark VI.1. For the case where $\rho^{(i)}(Z^{[i]})$ is $\text{AV@R}_\alpha(Z^{[i]})$, according to Proposition V.1, the risk of $Z^{[i]}$ is

$$\rho^{(i)}(Z^{[i]}) = \min_{\substack{\xi^{[i]} \geq 0_{|\mathbf{child}(i)|} \\ \alpha \xi^{[i]} \geq Z^{[i]} - t^{(i)} 1_{|\mathbf{child}(i)|}}} (t^{(i)} + \mathbf{E}_{\pi^{[i]}}(\xi^{[i]})) \quad (31)$$

with $t^{(i)} \in \mathbb{R}$ and $\xi^{[i]} = [\xi^{(i_+)}]_{i_+ \in \mathbf{child}(i)}$, $\xi^{(i_+)} \in \mathbb{R}$ for $i \in \mathbb{N}_{[0, \mu-1]} \setminus \mathbf{nodes}(N)$. As we consider the probability space $\mathbf{child}(i)$, we are interested in the probability of visiting $i_+ \in \mathbf{child}(i)$ given that we are at node i . Therefore, the probabilities are $\pi^{[i]} = [\pi^{(i_+)}/\pi^{(i)}]_{i_+ \in \mathbf{child}(i)}$ and (31) is equivalent to

$$\rho^{(i)}(Z^{[i]}) = \min_{\substack{\xi^{[i]} \geq 0_{|\mathbf{child}(i)|} \\ \alpha \xi^{[i]} \geq Z^{[i]} - t^{(i)} 1_{|\mathbf{child}(i)|}}} (t^{(i)} + \sum_{i_+ \in \mathbf{child}(i)} \frac{\pi^{(i_+)}}{\pi^{(i)}} \xi^{(i_+)}). \quad (32)$$

Having discussed conditional risk mappings on scenario trees, we can now use them to construct a multistage risk measure based on the vector $Z = [Z_1^\top \dots Z_N^\top]^\top$ that is associated with the multistage random variable.

B. Risk-averse optimal control

Let $Z_j \in \mathbb{R}^{|\mathbf{nodes}(j)|}$ be the cost in (20). For the sequence (Z_1, \dots, Z_N) and given a sequence of conditional risk mappings ρ_j of the form (30), the nested multistage risk measure $\varrho_N : \mathbb{R}^{|\mathbf{nodes}(1)|} \times \dots \times \mathbb{R}^{|\mathbf{nodes}(N)|} \rightarrow \mathbb{R}$ is [28], [29], [30]

$$\begin{aligned} \varrho_N(Z_1, \dots, Z_N) &= \\ \rho_0(Z_1 + \rho_1(Z_2 + \dots + \rho_{N-1}(Z_N)) \dots). \end{aligned} \quad (33)$$

Nested multistage risk measures possess favourable properties which render them suitable for optimal control formulations.

The most important properties are that they (i) are suitable for multistage formulations as they measure how risk propagates over time, (ii) are coherent risk measures over the space $\mathbb{R}^{|\text{nodes}(1)|} \times \dots \times \mathbb{R}^{|\text{nodes}(N)|}$ [30, Sec. 6.8], (iii) give rise to optimal control problems which are amenable to dynamic programming formulations [65], (iv) allow for MPC formulations with closed-loop stability guarantees [29], [28].

The definition of ϱ_N in (33) allows to formulate the following optimisation problem with decision variables $\mathbf{v} = [v^{(i)}]_{i \in \mathbb{N}_{[0, \mu-1]}}$, $\mathbf{x} = [x^{(i)}]_{i \in \mathbb{N}_{[0, \mu-1]}}$, $\mathbf{q} = [q^{(i)}]_{i \in \mathbb{N}_{[0, \mu-1]}}$.

Problem 1. Solve the optimal control problem

$$\text{Minimise}_{\mathbf{v}, \mathbf{x}, \mathbf{q}} \varrho_N(Z_1, \dots, Z_N)$$

subj. to

$$\begin{aligned} & \text{constraints (15) and given initial conditions } x^{(0)}, \delta_t^{(0-)} \\ & \forall i_+ \in \mathbb{N}_{[1, \mu-1]} \text{ and } i = \text{anc}(i_+). \end{aligned}$$

Note that the cost function is the composition of a series of, typically, nonsmooth mappings. Such problems have been studied in the operations research literature and are typically solved by means of cutting plane methods which allow the solution of problems with short prediction horizons and linear stage cost functions [31], [32]. Here, we employ the method introduced in [28] to decompose the nested conditional risk mappings and reformulate Problem 1 as an MIQCQP.

C. Reformulation as an MIQCQP

In this section we employ (32) to decompose the nested formulation stated above for the case of AVaR. By doing so, we will cast the overall MPC problem as an MIQCQP.

Theorem VI.2 (Problem reformulation). Define the variables $t^{(i)}$ for all non-leaf nodes i and the variables $\xi^{(i_+)}$ for all nodes $i_+ \in \mathbb{N}_{[1, \mu-1]}$. Define

$$\Psi^{(i)} = t^{(i)} + \sum_{i_+ \in \text{child}(i)} \frac{\pi^{(i_+)}}{\pi^{(i)}} \xi^{(i_+)},$$

for all non-leaf nodes i , which is the cost in the minimisation in (32). Let the underlying risk measure be the average value-at-risk at level $\alpha \in [0, 1]$. Then, with the additional decision variables $\mathbf{t} = [t^{(i)}]_{i \in (\mathbb{N}_{[0, \mu-1]} \setminus \text{nodes}(N))}$ and $\boldsymbol{\xi} = [\xi^{(i)}]_{i \in \mathbb{N}_{[1, \mu-1]}}$, Problem 1 is equivalent to the following problem, in the sense that both problems yield equal optimal values.

Problem 2. Solve the optimisation problem

$$\text{Minimise}_{\mathbf{v}, \mathbf{x}, \mathbf{q}, \mathbf{t}, \boldsymbol{\xi}} \Psi^{(0)}$$

subj. to

$$\begin{aligned} & \xi^{[i]} \geq 0, \\ & \alpha \xi^{[i]} \geq Z^{[i]} - t^{(i)} 1_{|\text{child}(i)|}, \text{ if } \text{stage}(i) = N - 1 \\ & \alpha \xi^{[i]} \geq Z^{[i]} + \Psi^{[i]} - t^{(i)} 1_{|\text{child}(i)|}, \text{ if } \text{stage}(i) < N - 1 \\ & \text{constraints (15) and given initial conditions } x^{(0)}, \delta_t^{(0-)} \\ & \forall i_+ \in \mathbb{N}_{[1, \mu-1]} \text{ and } i = \text{anc}(i_+). \end{aligned}$$

Proof. Let us introduce a vector $\Phi \in \mathbb{R}^{\mu - |\text{nodes}(N)|}$, which is defined over the non-leaf nodes of the scenario tree. In

particular, we associate a value $\Phi^{(i)} \in \mathbb{R}$ to every non-leaf node $i \in \mathbb{N}_{[0, \mu-1]} \setminus \text{nodes}(N)$. Similar to (20), we segment Φ stage-wise into $\Phi_j = [\Phi^{(i)}]_{i \in \text{nodes}(j)}$. Let us first define $\Phi_{N-1} \in \mathbb{R}^{|\text{nodes}(N-1)|}$ over the set $\text{nodes}(N-1)$ as

$$\Phi_{N-1} = \rho_{N-1}(Z_N). \quad (34a)$$

Φ_{N-1} is the conditional value-at-risk at stage $N-1$ and it corresponds to the innermost term in the nested multistage cost function (33) in Problem 1. Furthermore, let us define $\Phi_j \in \mathbb{R}^{|\text{nodes}(j)|}$ over the set $\text{nodes}(j)$, $j \in \mathbb{N}_{[0, N-2]}$ as

$$\Phi_j = \rho_j(Z_{j+1} + \Phi_{j+1}). \quad (34b)$$

The recursive definition (34) allows us to express the nested multistage risk measure (33) as

$$\begin{aligned} \varrho_N(Z_1, \dots, Z_N) &= \rho_0(Z_1 + \rho_1(Z_2 + \dots \\ & \quad + \rho_{N-2}(Z_{N-1} + \Phi_{N-1})) \dots) \\ & \quad \vdots \\ &= \rho_0(Z_1 + \Phi_1) = \Phi_0. \end{aligned} \quad (35)$$

Note that Φ_{N-1} in (34a) is composed of elements $\Phi^{(i)}$, $i \in \text{nodes}(N-1)$ and because of (32),

$$\Phi^{(i)} = \rho^{(i)}(Z^{[i]}) = \min_{\substack{\xi^{[i]} \geq 0 \\ \alpha \xi^{[i]} \geq Z^{[i]} - t^{(i)} 1_{|\text{child}(i)|}}} \Psi^{(i)}, \quad (36)$$

where the minimisation is carried out over the decision variables $t^{(i)}$ and $\xi^{[i]} = [\xi^{(i_+)}]_{i_+ \in \text{child}(i)}$.

The vector Φ_j in (34b) comprises the elements $\Phi^{(i)}$, $\text{stage}(i) = j$. For AVaR, as described in (32) they are

$$\Phi^{(i)} = \rho^{(i)}(Z^{[i]} + \Phi^{[i]}) = \min_{\substack{\xi^{[i]} \geq 0 \\ \alpha \xi^{[i]} \geq Z^{[i]} + \Phi^{[i]} - t^{(i)} 1_{|\text{child}(i)|}}} \Psi^{(i)} \quad (37)$$

In light of (35), the above recursive procedure leads to the formulation of the following optimisation problem.

Problem 3. Solve the optimisation problem

$$\text{Minimise}_{\mathbf{v}, \mathbf{x}, \mathbf{q}, \mathbf{t}, \boldsymbol{\xi}} \Phi^{(0)}$$

subj. to

$$\begin{aligned} & \xi^{[i]} \geq 0, \\ & \alpha \xi^{[i]} \geq Z^{[i]} - t^{(i)} 1_{|\text{child}(i)|}, \text{ if } \text{stage}(i) = N - 1, \\ & \alpha \xi^{[i]} \geq Z^{[i]} + \Phi^{[i]} - t^{(i)} 1_{|\text{child}(i)|}, \text{ if } \text{stage}(i) < N - 1, \\ & \text{constraints (15) and given initial conditions } x^{(0)}, \delta_t^{(0-)} \\ & \forall i_+ \in \mathbb{N}_{[1, \mu-1]} \text{ and } i = \text{anc}(i_+). \end{aligned}$$

In Problem 3, we substitute $\Phi^{(0)}$ with $\Psi^{(0)}$ in the cost function. Furthermore, because of Lemma A.1 we can replace the constraint $\alpha \xi^{[i]} \geq Z^{[i]} + \Phi^{[i]} - t^{(i)} 1_{|\text{child}(i)|}$ by the constraint $\alpha \xi^{[i]} \geq Z^{[i]} + \Psi^{[i]} - t^{(i)} 1_{|\text{child}(i)|}$. This leads to Problem 2 completing the proof. \square

Since the operating cost of Section IV involves quadratic functions and binary variables, Problem 2 is an MIQCQP. As we will demonstrate in Section VII, this can be solved efficiently by standard software such as CPLEX or Gurobi.




Fig. 7. MG considered in the simulation case study with storage, renewable and conventional unit as well as load. Each unit is connected to a bus, which is connected with other buses by transmission lines.

D. Risk-averse MPC

The risk-averse optimal control problem is solved given the current measured state of the system and a scenario tree that describes the distribution of future available renewable infeed and demand over N stages. By solving Problem 2 at every time instant k we obtain a set of control actions $v^{(i)}$ for $i \in \mathbb{N}_{[0, \mu-1]} \setminus \text{nodes}(N)$ (see Figure 3). Then, the control action associated with the root node of the tree, $v^{(0)}$, is applied to the system. This procedure is repeated at every time instant $k \in \mathbb{N}_0$ in a receding horizon fashion leading to a risk-averse model predictive control (MPC) scheme [49].

VII. CASE STUDY

In this case study, we aim to demonstrate the properties of the risk-averse model predictive control strategy introduced in Section VI-D. For the simulations, the MG in Figure 7 is used. It comprises a storage, a conventional and a renewable unit with the parameters from Table II as well as a load. The units and the load are connected by transmission lines that all have susceptance $b_{ij} = -20$ pu and conductance $g_{ij} = 2$ pu. Hence, (12a) becomes

$$\begin{bmatrix} p_{e,1}(k) \\ p_{e,2}(k) \\ p_{e,3}(k) \\ p_{e,4}(k) \end{bmatrix} = \underbrace{\begin{bmatrix} 1 & 0 & 0 & 0 \\ 0 & -1/3 & 1/3 & 0 \\ 0 & 2/3 & 1/3 & 0 \\ 0 & 1/3 & 2/3 & 0 \end{bmatrix}}_F \begin{bmatrix} p_t(k) \\ p_s(k) \\ p_r(k) \\ w_d(k) \end{bmatrix}.$$

Each line can transmit power between -1.3 pu and 1.3 pu. Note that all values are given in per-unit (pu), see, e.g., [52].

All simulations were performed in MATLAB 2015a using the closed-loop setup shown in Figure 1. In what follows, we will discuss the different parts of it, i.e., forecast, scenario reduction, MPC and the MG plant model.

The wind speed and load forecasts were obtained with the seasonal ARIMA models from [20]. These were implemented using MATLAB's Econometrics toolbox. The available power of the RES, i.e., of the wind turbine, was calculated from the wind speed forecast using the cubic approximation from [20].

The scenario tree was generated from a collection of 500 independent scenarios of load and available renewable power using [60, Algorithm 5]. The maximum number of children per node was chosen to be 6 for the root node, 2 for the nodes of stage 1 and 1 for all other stages. The tree was modified to include high-effect low-probability scenarios corresponding to the cases of very low available renewable power and very

TABLE II
UNIT PARAMETERS AND WEIGHTS OF COST FUNCTION.

Parameter	Value	Weight	Value
$[p_t^{\min}, p_r^{\min}, p_s^{\min}]$	$[0.4, 0, -1]$ pu	c_t	0.1178
$[p_t^{\max}, p_r^{\max}, p_s^{\max}]$	$[1, 2, 1]$ pu	c_t'	0.751 1/pu
$[x^{\min}, x^{\max}]$	$[0, 7]$ pu h	c_t''	0.0693 1/pu
$[\tilde{x}^{\min}, \tilde{x}^{\max}]$	$[0.5, 6.5]$ pu h	c_r	1 1/pu
x^0	3 pu h	c_s	$3 \cdot 10^3 \text{ 1/pu h}$
$[K_t, K_s]$	$[1, 1]$	c_t^{sw}	0.1

high load and vice versa. Hence, the scenario tree contains $6 \cdot 2 + 2 = 14$ scenarios. Because of their very low probability, high-effect low-probability scenarios have minor influence on the stochastic case at $\alpha = 1$. However, for smaller values of α that are close to zero, i.e., as we approach the worst-case, their influence increases significantly as will be illustrated later.

For MPC, a prediction horizon of $N = 8$, a sampling time of $T_s = 1/2$ h and a discount factor of $\gamma = 0.95$ were chosen. The different controllers were implemented using YALMIP R20180612 [66] and Gurobi 7.5.2 as a numerical solver. To speed up the computations, the results from the previous iteration were used as initial values to warm-start the optimisation. Furthermore, the binary switch state of the conventional unit was relaxed for all stages greater than 3, i.e., $\delta_t^{(i)} \in [0, 1]^T$ for $\text{stage}(i) \geq 4$ in the risk-averse MPC. The simulations in Section VII-A were performed on a computer with an Intel® Xeon® E5-1620 v2 processor @3.70 GHz with 32 GB RAM. Here, the maximum solve time of Gurobi (excluding the time required by YALMIP to parse the problem) was below 7 s (see Table III). Considering a sampling time of $T_s = 1/2$ h (see, e.g., [67]), this is adequately fast.

In the plant model, the efficiency of the storage unit and an AC power flow model were considered to obtain more realistic simulation results. For the storage unit, the model described in Remark II.5 with charging and discharging efficiency $\eta^c = \eta^d = 0.92$ and self discharge $x^{\text{sd}} = 2 \cdot 10^{-3}$ pu h was used. For AC power flow, the model from Remark II.7 was used employing the MATLAB function `fmincon`. Here, the line parameters posed earlier and voltages $v_i = 1$ pu, $i \in \mathbb{N}_{[1,4]}$ were assumed. Note that this model was only used to simulate the MG plant and not in the MPC problem formulations.

To compare the outcome of the different simulations we introduce the average economically motivated cost

$$\bar{\ell}_o = \frac{1}{K} \sum_{k=1}^K \ell_o(v_s(k-1), v(k), z(k)). \quad (38a)$$

over a simulation horizon K with ℓ_o from (17). Using (19), we also introduce the average cost related to the stored energy,

$$\bar{\ell}_s = \frac{1}{K} \sum_{k=1}^K \ell_s(x(k)). \quad (38b)$$

Having described the simulation setup and the average costs, we can now discuss the simulation results. Here, we first provide a comparison of different controllers for a nominal simulation run. Then, we illustrate the properties of the risk-averse MPC in more detail in a sensitivity analysis.




Fig. 8. Power and energy of the MG using different controllers over one week of simulation with a sampling time of $\frac{1}{2}$ h.

TABLE III
RUNNING COSTS, CONVENTIONAL AND RENEWABLE INFEEED OF
CLOSED-LOOP SIMULATION WITH SIMULATION HORIZON $K = 336$.

	Certainty- equival.	Risk-averse, $\alpha =$		
		0.0 ^a	0.5	1.0 ^b
Avg. power costs $\bar{\ell}_o$	2.79	3.2	2.82	2.75
Avg. energy cost $\bar{\ell}_s$	5.82	0	0.17	1.34
Avg. conventional infeed in pu	0.18	0.28	0.18	0.17
Avg. infeed of RES in pu	0.43	0.33	0.42	0.44
Constraint violations power	6	0	0	0
Switching actions	13	11	11	15
Avg. solve time in s	0.01	0.26	0.34	0.75
Maximum solve time in s	0.06	5.01	2.44	6.29

^a Corresponds to worst-case MPC.

^b Corresponds to risk-neutral stochastic (expectation-based) MPC.

A. Nominal simulations

In what follows, the risk-averse MPC approach for different values of α and a certainty-equivalent MPC approach where the mean value of the forecast is considered as the true value [10] are compared in closed-loop simulations. As shown in Table III, the certainty-equivalent approach leads to power constraint violations. These are caused by the discrepancy between data-based forecast and actual uncertain input, as well as the mismatch between the model in MPC and in the plant simulation and render the approach unsuitable for a safe operation control. Therefore, it is not discussed further.

For the risk-averse approaches, it can be seen in Figure 8 that with increasing α , energy is stored faster. Furthermore, the mean infeed from RES increases and the infeed of the

conventional unit decreases (see Table III). These two effects contribute significantly to a decrease of the cost $\bar{\ell}_o$. Thus, with $\alpha = 1$, the cost $\bar{\ell}_o$ is reduced by 14 % compared to $\alpha = 0$.

As the approach becomes more averse to risk with decreasing α , the average cost associated with the stored energy, $\bar{\ell}_s$, decreases. Two effects drive this decrease: (i) the handling of high-effect low-probability (HELP) scenarios in MPC and (ii) the mismatch between the MG model in the plant simulation and that in MPC. However, simulations where the same model is used for the MG plant and MPC indicate that effect (i) plays the dominant role.

HELP scenarios represent extreme combinations of forecast values which are very unlikely to happen. A misestimation of their probability can have a strong impact on the closed-loop performance. Risk-neutral stochastic MPC ($\alpha = 1$) is agnostic to such misestimations and can therefore not act proactively against misestimated HELP events. In closed-loop simulations, this is reflected by higher energy related costs, $\bar{\ell}_s$, as probability distributions that do not follow the scenario tree are not considered. With decreasing α , ambiguity in the probability distribution is taken more into account leading to MPC formulations that account for misestimated probabilities of unlikely events. This leads to an increasing importance of unlikely scenarios where the energy is outside the interval $[\hat{x}^{\min}, \hat{x}^{\max}]$ and results in control actions where more energy values are inside this interval leading to lower values of $\bar{\ell}_s$.

A comparison of the overall average cost, $\bar{\ell} = \bar{\ell}_o + \bar{\ell}_s$, shows that the lowest value $\bar{\ell} = 2.99$ is achieved for $\alpha = 0.5$. This is about 6 % lower than the overall cost for $\alpha = 0$, $\bar{\ell} = 3.2$, and about 26 % lower than the overall cost for $\alpha = 1$, $\bar{\ell} = 4.09$.

The nominal simulations show that the risk-averse MPC




Fig. 9. 1000 scenarios of wind and load data used in sensitivity analysis with constant offset of 1.5 times the standard deviation.




Fig. 10. Results of sensitivity analysis with systematic error, i.e., constant offset in the mean value of the additional disturbance.

together with an appropriate construction of the scenario tree leads to suitable operation strategies for islanded MGs. In practice, this translates into a desirable trade-off between performance and robustness to uncertain probability distributions.

B. Sensitivity analysis

To illustrate the performance of the risk-averse approach in presence of inaccurate forecasts, a sensitivity analysis was carried out. In the analysis, 1000 closed-loop simulations were performed for the first three days, i.e., $K = 144$ simulation steps, of the scenario shown in Figure 8. To demonstrate the robustness of the risk-averse approach to uncertainty in the probability distribution, we added noise to the uncertain input of the MG plant model. This way, occasional HELP events are artificially added to illustrate the positive effects of the risk-averse MPC approach. In the following analysis, we consider two different probability distributions of the additional noise: (i) constant offset in the mean value, and (ii) occasional offset that randomly occurs in 10% of the simulation steps.

1) *Disturbance with constant offset*: Here, a Gaussian noise term with nonzero mean and standard deviation equal to that of the ARIMA forecast training residuals is added to the wind speed and load time series. In particular, Gaussian noise with mean 0.048 pu and standard deviation 0.032 pu was added to the load and Gaussian noise with mean -0.795 m/s and standard deviation 0.53 m/s was added to the wind speed before the available wind power, w_r , was obtained. The different scenarios of wind and load are shown in Figure 9.

The resulting distribution of $\bar{\ell}_o$ is illustrated in Figure 10. It can be observed that the mean of the economically motivated costs first decrease from $\alpha = 1$ to $\alpha = 0.5$ by 0.14%. Furthermore, the standard deviation of $\bar{\ell}_o$ significantly decreases from 0.019 for $\alpha = 1$ to 0.012 for $\alpha = 0.5$. Then,




Fig. 11. 1000 scenarios of wind and load data used in sensitivity analysis with occasional extreme events in 10% of the cases.




Fig. 12. Results of sensitivity analysis with occasional extreme events in 10% of the cases.

for $\alpha = 0$ the mean of $\bar{\ell}_o$ increases by 9.3% due to the increased conservativeness of the robust MPC approach. This shows that choosing $\alpha < 1$ can protect the system from HELP events, i.e., prevent extreme costs, and even reduce closed-loop costs. This is also reflected in the lower standard deviation of cost for smaller values of α . Furthermore, the energy related costs $\bar{\ell}_s$ decrease for smaller values of α . Thus, by choosing α appropriately, the costs and the conservativeness of the control scheme can be tuned. This adds an important degree of freedom to the traditional design procedures of worst-case ($\alpha = 0$) and stochastic ($\alpha = 1$) approaches.

2) *Disturbance with occasional extreme events*: Here, the mean value of the additional noise was chosen different from zero for only 10% of the data points to model occasional extreme events. For the other data points, the mean of the additional noise was set to zero. The random nonzero offset in 10% of the cases was 0.096 pu for load and 1.589 m/s for wind speed. A standard deviation of 0.032 pu for load and 0.53 m/s for wind speed was considered for all cases based on the training residuals of the ARIMA forecast models. This led to the scenarios shown in Figure 11.

As shown in Figure 12, the energy related costs $\bar{\ell}_s$ decreases for lower values of α , yet, lower economically motivated costs $\bar{\ell}_o$, are not observed as α decreases. However, the standard deviation of $\bar{\ell}_o$ decreases from 0.024 for $\alpha = 1$ to 0.007 for $\alpha = 0$, indicating that the average cost for operating the grid becomes less sensitive to inaccurate probability distributions with decreasing α . This shows that the importance of HELP events can be explicitly parametrised by adapting α . Additionally, for a given MG setup, the designer of the MPC has a tuning knob to strike a suitable trade-off between the economically motivated $\bar{\ell}_o$ and the state related $\bar{\ell}_s$.

VIII. CONCLUSIONS

In this work we presented a risk-averse MPC strategy for islanded MGs with very high share of RES which enables us to trade economic performance for safety by interpolating between worst-case and risk-neutral stochastic formulations. The approach provides resilience with respect to misestimations of the underlying probability distributions of demand and available renewable infeed. Therefore, it is suitable for practical implementations, where these distributions are not known exactly or change over time. It also allows for the use of simple and therefore computationally less expensive scenario trees at the expense of operating with a slightly more conservative regime. Furthermore, the presented MPC scheme is able to protect MGs against high-effect low-probability events such as sudden drops of available renewable power or unexpected increase of demand. Finally, the proposed risk-averse MPC formulation can be cast as an MIQCQP which can be solved by commercial solvers as indicated in Section VI.

For a large number of integer variables the problem complexity can potentially become prohibitive. In the future we would like to look into this topic in more detail by considering MGs with more conventional and renewable units as well as scenario trees with a higher number of nodes. Furthermore, as the operation regime is significantly influenced by the state of charge, we plan to consider more complex storage dynamics. Future work will also address chance constraints and decreasing the solver time by devising parallelisable optimisation algorithms (see, e.g., [68]) that can run on graphics processing units. Also, we plan to study statistically meaningful ways to choose the level of risk aversion (see, e.g., [69]).

APPENDIX A AUXILIARY RESULTS

Lemma A.1. Let $\emptyset \neq \mathbb{X} \subseteq \mathbb{R}^n$, $\emptyset \neq \mathbb{Y} \subseteq \mathbb{R}^m$ and for every $x \in \mathbb{X}$, $f(x, y)$ attains a minimum over \mathbb{Y} , i.e., $\min_{y \in \mathbb{Y}} f(x, y)$ exists. Then, the optimisation problem

$$\underset{x \in \mathbb{X}, v}{\text{Minimise}} F(x, v) \quad \text{subj. to} \quad \min_{y \in \mathbb{Y}} f(x, y) \leq \beta,$$

with cost function $F : \mathbb{R}^n \times \mathbb{R}^m \rightarrow \mathbb{R}$ is equivalent to

$$\underset{x \in \mathbb{X}, v}{\text{Minimise}} F(x, v) \quad \text{subj. to} \quad y \in \mathbb{Y}, f(x, y) \leq \beta.$$

Proof. As the two problems have the same cost function, it suffices to show that they have the same constraint sets. Therefore, we define $\mathbb{S} = \{x \in \mathbb{R}^n \mid \min_{y \in \mathbb{Y}} f(x, y) \leq \beta\}$ and $\mathbb{S}' = \{x \in \mathbb{R}^n \mid \exists y \in \mathbb{Y} \text{ such that } f(x, y) \leq \beta\}$.

Take $x \in \mathbb{S}$, i.e., $\min_{y \in \mathbb{Y}} f(x, y) \leq \beta$. Since the minimum exists, there is a $y^* \in \mathbb{Y}$ such that $f(x, y^*) \leq \beta$. Hence, $x \in \mathbb{S}'$ and consequently $\mathbb{S} \subseteq \mathbb{S}'$.

Take $x \in \mathbb{S}'$, i.e., there is a $y_0 \in \mathbb{Y}$ such that $f(x, y_0) \leq \beta$. Then, $x \in \mathbb{S}$ because $\min_{y \in \mathbb{Y}} f(x, y) \leq f(x, y_0) \leq \beta$, and consequently $\mathbb{S}' \subseteq \mathbb{S}$. This proves that $\mathbb{S}' = \mathbb{S}$. \square

REFERENCES

- [1] N. Hatziaargyriou, H. Asano, R. Iravani, and C. Marnay, "Microgrids," *IEEE Power Energy Mag.*, vol. 5, no. 4, pp. 78–94, 2007.
- [2] R. H. Lasseter, "MicroGrids," in *IEEE PES WM*, 2002, pp. 305–308.
- [3] J. A. Peças Lopes, C. L. Moreira, and A. G. Madureira, "Defining control strategies for microgrids islanded operation," *IEEE Trans. Power Syst.*, vol. 21, no. 2, pp. 916–924, 2006.
- [4] A. Bidram and A. Davoudi, "Hierarchical structure of microgrids control system," *IEEE Trans. Smart Grid*, vol. 3, no. 4, pp. 1963–1976, 2012.
- [5] F. Katiraei, N. Iravani, N. Hatziaargyriou, and A. Dimeas, "Microgrids management," *IEEE Power Energy Mag.*, vol. 6, no. 3, pp. 54–65, 2008.
- [6] A. G. Tsikalakis and N. D. Hatziaargyriou, "Centralized control for optimizing microgrids operation," in *IEEE PES GM*, 2011, pp. 1–8.
- [7] A. Parisio, E. Rikos, and L. Glielmo, "A model predictive control approach to microgrid operation optimization," *IEEE Trans. Control Syst. Technol.*, no. 99, 2014.
- [8] R. Palma-Behnke, C. Benavides, F. Lanas, B. Severino, L. Reyes, J. Llanos, and D. Sáez, "A microgrid energy management system based on the rolling horizon strategy," *IEEE Trans. Smart Grid*, vol. 4, no. 2, pp. 996–1006, 2013.
- [9] D. Olivares, C. Cañizares, and M. Kazerani, "A centralized energy management system for isolated microgrids," *IEEE Trans. Smart Grid*, vol. 5, no. 4, pp. 1864–1875, 2014.
- [10] C. A. Hans, V. Nenchev, J. Raisch, and C. Reincke-Collon, "Minimax model predictive operation control of microgrids," in *IFAC WC*, 2014, pp. 10 287–10 292.
- [11] I. Prodan and E. Zio, "A model predictive control framework for reliable microgrid energy management," *Int. J. Electr. Power Energy Syst.*, vol. 61, pp. 399–409, 2014.
- [12] C. A. Hans, V. Nenchev, J. Raisch, and C. Reincke-Collon, "Approximate closed-loop minimax model predictive operation control of microgrids," in *ECC*, 2015, pp. 241–246.
- [13] P. Kou, D. Liang, L. Gao, and F. Gao, "Stochastic coordination of plug-in electric vehicles and wind turbines in microgrid: A model predictive control approach," *IEEE Trans. Smart Grid*, vol. 7, no. 3, pp. 1537–1551, 2016.
- [14] M. Gulin, J. Matuško, and M. Vašak, "Stochastic model predictive control for optimal economic operation of a residential DC microgrid," in *IEEE ICIT*, March 2015, pp. 505–510.
- [15] S. Raimondi Cominesi, M. Farina, L. Giulioni, B. Picasso, and R. Scatoloni, "A two-layer stochastic model predictive control scheme for microgrids," *IEEE Trans. Control Syst. Technol.*, vol. 26, no. 1, pp. 1–13, 2018.
- [16] A. Hooshmand, M. H. Poursaeidi, J. Mohammadpour, H. A. Malki, and K. Grigoriadis, "Stochastic model predictive control method for microgrid management," in *IEEE PES ISGT*, 2012, pp. 1–7.
- [17] A. Mesbah, "Stochastic model predictive control: An overview and perspectives for future research," *IEEE Control Syst. Mag.*, vol. 36, no. 6, pp. 30–44, 2016.
- [18] F. Oldewurtel, C. N. Jones, and M. Morari, "A tractable approximation of chance constrained stochastic MPC based on affine disturbance feedback," in *IEEE CDC*, 2008, pp. 4731–4736.
- [19] P. Kou, D. Liang, and L. Gao, "Stochastic energy scheduling in microgrids considering the uncertainties in both supply and demand," *IEEE Syst. J.*, vol. 12, no. 3, pp. 2589–2600, 2018.
- [20] C. A. Hans, P. Sopasakis, A. Bemporad, J. Raisch, and C. Reincke-Collon, "Scenario-based model predictive operation control of islanded microgrids," in *IEEE CDC*, 2015.
- [21] M. Petrollese, L. Valverde, D. Cocco, G. Cau, and J. Guerra, "Real-time integration of optimal generation scheduling with MPC for the energy management of a renewable hydrogen-based microgrid," *Appl. Energy*, vol. 166, pp. 96–106, 2016.
- [22] A. Parisio, E. Rikos, and L. Glielmo, "Stochastic model predictive control for economic/environmental operation management of microgrids: An experimental case study," *J. Process Control*, vol. 43, pp. 24–37, 2016.
- [23] A. Maulik and D. Das, "Optimal operation of droop-controlled islanded microgrids," *IEEE Trans. Sustain. Energy*, vol. PP, no. 99, p. 1, 2017.
- [24] B. Heymann, J. F. Bonnans, F. Silva, and G. Jimenez, "A stochastic continuous time model for microgrid energy management," in *ECC*, 2016, pp. 2084–2089.
- [25] P. Pinson, H. Madsen, H. A. Nielsen, G. Papaefthymiou, and B. Klöckl, "From probabilistic forecasts to statistical scenarios of short-term wind power production," *Wind Energy*, vol. 12, no. 1, pp. 51–62, 2009.
- [26] H. Heitsch and W. Römisch, "Scenario reduction algorithms in stochastic programming," *Comput. Optimization. Appl.*, vol. 24, no. 2-3, pp. 187–206, 2003.
- [27] H. Heitsch and W. Römisch, "Scenario tree modeling for multistage stochastic programs," *Math. Prog.*, vol. 118, no. 2, pp. 371–406, 2009.
- [28] P. Sopasakis, D. Herceg, A. Bemporad, and P. Patrinos, "Risk-averse model predictive control," *Automatica*, vol. 100, pp. 281–288, 2019.

- [29] Y.-L. Chow and M. Pavone, "A framework for time-consistent, risk-averse model predictive control: Theory and algorithms," in *ACC*, 2014, pp. 4204–4211.
- [30] A. Shapiro, D. Dentcheva, and A. Ruszczyński, *Lectures on stochastic programming: modeling and theory*, 2nd ed. Philadelphia, PA, USA: SIAM, 2014.
- [31] T. Asamov and A. Ruszczyński, "Time-consistent approximations of risk-averse multistage stochastic optimization problems," *Math. Prog.*, vol. 153, no. 2, pp. 459–493, 2015.
- [32] S. Bruno, S. Ahmed, A. Shapiro, and S. Stree, "Risk neutral and risk averse approaches to multistage renewable investment planning under uncertainty," *Eur. J. Oper. Res.*, vol. 250, no. 3, pp. 979–989, 2016.
- [33] P. Patrinos and H. Sarimveis, "Convex parametric piecewise quadratic optimization: theory and algorithms," *Automatica*, vol. 47, no. 8, pp. 1770–1777, 2011.
- [34] —, "An explicit optimal control approach for mean-risk dynamic portfolio allocation," in *ECC*, 2007, pp. 3364–3370.
- [35] R. Khodabakhsh and S. Sirouspour, "Optimal control of energy storage in a microgrid by minimizing conditional value-at-risk," *IEEE Trans. Sustain. Energy*, vol. 7, no. 3, pp. 1264–1273, 2016.
- [36] C. Zhao and R. Jiang, "Distributionally robust contingency-constrained unit commitment," *IEEE Trans. Power Syst.*, vol. 33, no. 1, pp. 94–102, 2018.
- [37] J. García-González, E. Parrilla, and A. Mateo, "Risk-averse profit-based optimal scheduling of a hydro-chain in the day-ahead electricity market," *Eur. J. Oper. Res.*, vol. 181, no. 3, pp. 1354–1369, 2007.
- [38] I. G. Moghaddam, M. Nick, F. Fallahi, M. Sanei, and S. Mortazavi, "Risk-averse profit-based optimal operation strategy of a combined wind farm-cascade hydro system in an electricity market," *Renewable Energy*, vol. 55, pp. 252–259, 2013.
- [39] Y. Zhang, S. Shen, and J. L. Mathieu, "Distributionally robust chance-constrained optimal power flow with uncertain renewables and uncertain reserves provided by loads," *IEEE Trans. Power Syst.*, vol. 32, no. 2, pp. 1378–1388, 2017.
- [40] T. Summers, J. Warrington, M. Morari, and J. Lygeros, "Stochastic optimal power flow based on conditional value at risk and distributional robustness," *Int. J. Electr. Power Energy Syst. Eng.*, vol. 72, pp. 116–125, 2015.
- [41] L. Roald, M. Vrakopoulou, F. Oldewurtel, and G. Andersson, "Risk-based optimal power flow with probabilistic guarantees," *Int. J. Electr. Power Energy Syst.*, vol. 72, pp. 66–74, 2015.
- [42] M. Maceira, L. Marzano, D. Penna, A. Diniz, and T. Justino, "Application of CVaR risk aversion approach in the expansion and operation planning and for setting the spot price in the brazilian hydrothermal interconnected system," *Int. J. Electr. Power Energy Syst.*, vol. 72, pp. 126–135, 2015.
- [43] J. M. Morales, A. J. Conejo, and J. Pérez-Ruiz, "Short-term trading for a wind power producer," *IEEE Trans. Power Syst.*, vol. 25, no. 1, pp. 554–564, 2010.
- [44] P. Patrinos, S. Trimoli, and A. Bemporad, "Stochastic MPC for real-time market-based optimal power dispatch," in *IEEE CDC and ECC*, 2011, pp. 7111–7116.
- [45] A. Botterud, Z. Zhou, J. Wang, R. J. Bessa, H. Keko, J. Sumaili, and V. Miranda, "Wind power trading under uncertainty in LMP markets," *IEEE Trans. Power Syst.*, vol. 27, no. 2, pp. 894–903, 2012.
- [46] A. Krishna, C. A. Hans, J. Schiffer, J. Raisch, and T. Kral, "Steady state evaluation of distributed secondary frequency control strategies for microgrids in the presence of clock drifts," in *MED*, 2017.
- [47] J. Schiffer, C. A. Hans, T. Kral, R. Ortega, and J. Raisch, "Modelling, analysis and experimental validation of clock drift effects in low-inertia power systems," *IEEE Trans. Ind. Electron.*, vol. 64, no. 7, pp. 5942–5951, 2017.
- [48] K. Purchala, L. Meeus, D. Van Dommelen, and R. Belmans, "Usefulness of DC power flow for active power flow analysis," in *IEEE PES GM*, 2005, pp. 454–459.
- [49] A. Bemporad and M. Morari, "Control of systems integrating logic, dynamics, and constraints," *Automatica*, vol. 35, no. 3, pp. 407–427, 1999.
- [50] J. B. Rawlings and D. Q. Mayne, *Model predictive control: Theory and design*. Nob Hill Pub., 2009.
- [51] C. A. Hans, P. Braun, J. Raisch, L. Grüne, and C. Reincke-Collon, "Hierarchical distributed model predictive control of interconnected microgrids," *IEEE Trans. Sustain. Energy*, vol. 10, no. 1, pp. 407–416, 2019.
- [52] P. Kundur, N. J. Balu, and M. G. Lauby, *Power system stability and control*. McGraw-Hill, 1994, vol. 7.
- [53] S. H. Low, "Convex relaxation of optimal power flow—part I: Formulations and equivalence," *IEEE Trans. Control Netw. Syst.*, vol. 1, no. 1, pp. 15–27, 2014.
- [54] G. E. Box, G. M. Jenkins, and G. C. Reinsel, *Time series analysis: forecasting and control*. John Wiley & Sons, 2013.
- [55] G. C. Pflug and A. Pichler, "Dynamic generation of scenario trees," *Comput. Optimization Appl.*, vol. 62, no. 3, pp. 641–668, 2015.
- [56] J. M. Latorre, S. Cerisola, and A. Ramos, "Clustering algorithms for scenario tree generation: Application to natural hydro inflows," *Eur. J. Oper. Res.*, vol. 181, no. 3, pp. 1339–1353, 2007.
- [57] Z. Chen and D. Xu, "Knowledge-based scenario tree generation methods and application in multiperiod portfolio selection problem," *Appl. Stoch. Model. Bus. Ind.*, vol. 30, no. 3, pp. 240–257, 2014.
- [58] P. Beraldi, F. D. Simone, and A. Violi, "Generating scenario trees: A parallel integrated simulation-optimization approach," *J. Comput. Appl. Math.*, vol. 233, no. 9, pp. 2322–2331, 2010.
- [59] N. Gülpınar, B. Rustem, and R. Settergren, "Simulation and optimization approaches to scenario tree generation," *J. Econ. Dyn. Control*, vol. 28, no. 7, pp. 1291–1315, 2004.
- [60] C. Ocampo-Martinez, V. Puig, J. Grosso, G. Cembrano, P. Sotasakis, A. Sampathirao, P. Patrinos, D. Bernardini, G. Gnecco, and A. Bemporad, "Real-time control algorithms for optimal operational management," EFFINET, Tech. Rep., 2015.
- [61] M. Živić Đurović, A. Milačić, and M. Kršulja, "A simplified model of quadratic cost function for thermal generators," *Ann. DAAAM 2012 Proc. 23 Int. DAAAM Symp.*, vol. 23, no. 1, pp. 25–28, 2012.
- [62] J. Vetter, P. Novák, M. R. Wagner, C. Veit, K.-C. Möller, J. Besenhard, M. Winter, M. Wohlfahrt-Mehrens, C. Vogler, and A. Hammouche, "Ageing mechanisms in lithium-ion batteries," *J. Power Sources*, vol. 147, no. 1–2, pp. 269–281, 2005.
- [63] B. P. Van Parys, D. Kuhn, P. J. Goulart, and M. Morari, "Distributionally robust control of constrained stochastic systems," *IEEE Trans. Autom. Control*, vol. 61, no. 2, pp. 430–442, 2016.
- [64] S. Boyd and L. Vandenberghe, *Convex optimization*. Cambridge university press, 2004.
- [65] A. Shapiro, "Minimax and risk averse multistage stochastic programming," *Eur. J. Oper. Res.*, vol. 219, no. 3, pp. 719–726, 2012.
- [66] J. Löfberg, "YALMIP: A toolbox for modeling and optimization in MATLAB," in *IEEE CACSD*, 2004, pp. 284–289.
- [67] P. Braun, T. Faulwasser, L. Grüne, C. M. Kellett, S. R. Weller, and K. Worthmann, "Maximal islanding time for microgrids via distributed predictive control," in *22 Int. Symp. Math. Theory Netw. Syst.*, 2016, pp. 652–659.
- [68] A. K. Sampathirao, P. Sotasakis, A. Bemporad, and P. Patrinos, "GPU-accelerated stochastic predictive control of drinking water networks," *IEEE Trans. Control Syst. Technol.*, vol. 26, no. 2, pp. 551–562, 2018.
- [69] M. Schuurmans, P. Sotasakis, and P. Patrinos, "Safe learning-based control of stochastic jump linear systems: a distributionally robust approach," *arXiv e-print, 1903.10040*, 2019.



Christian A. Hans (S'13) is research assistant at the Control Systems Group in the EECS Department at TU Berlin. Prior to that, he engaged in control issues in low inertia microgrids as development engineer at Younicos AG, Germany. His research focuses on the application of control methods to power systems with very high share of renewable energy sources. Here, he is especially interested in model predictive operation control and time-series forecasting as well as distributed and decentralized control.



Pantelis Sopasakis is a lecturer at School of Electronics, Electrical Engineering and Computer Science (EEECs) at Queen's University Belfast and a member of Centre for Intelligent Autonomous Manufacturing Systems (i-AMS). He received a diploma (MEng) in Chemical Engineering in 2007 and an MSc with honours in Applied Mathematics in 2009 from National Technical University of Athens. In December 2012, he defended his PhD thesis at School of Chemical Engineering, NTU Athens. He has held postdoc positions at IMT Lucca (Italy,

2013-16), KU Leuven, ESAT (Belgium, 2016-18) and University of Cyprus, KIOS (Cyprus, 2018). His research interests focus on the development of model predictive control methodologies, numerical algorithms for large-scale stochastic systems and massive parallelisation on general-purpose graphics processing units (GP-GPUs). The outcomes of his research have several applications in automotive and aerospace, microgrids, water distribution networks and optimal, safe drug administration.



Panagiotis (Panos) Patrinos (M'13) is assistant professor at the Department of Electrical Engineering (ESAT) of KU Leuven, Belgium. During 2014 he held a visiting assistant professor position in the department of Electrical Engineering at Stanford University. He received his PhD in Control and Optimisation, M.S. in Applied Mathematics and M.Eng. from the National Technical University of Athens in 2010, 2005 and 2003, respectively. He has held postdoc positions at the University of Trento and IMT Lucca, Italy, where he became an assistant

professor in 2012.

His research interests lie in the interface of optimisation, learning and control with a broad range of applications including autonomous vehicles, smart grids, water networks, aerospace, multi-agent systems, signal processing and machine learning.

He was the chair of the 38th Benelux meeting on Systems and Control (2019) and co-chair of the 4th European Conference on Computational Optimization (EUCCO 2016).



Jörg Raisch studied Engineering Cybernetics at Stuttgart University and Control Systems at UMIST, Manchester. He received a PhD and a Habilitation degree, both from Stuttgart University. He holds the chair for Control Systems in the EECS Department at TU Berlin, and he is also an external scientific member of the Max Planck Institute for Dynamics of Complex Technical Systems. His main research interests are hybrid and hierarchical control, distributed cooperative control, and control of timed discrete-event systems in tropical algebras, with ap-

plications in chemical, medical, and power systems engineering.



Carsten Reincke-Collon is Director of Future Technology within the Global Products and Technology unit of Aggreko plc, a leading specialist provider of power, temperature control and energy services. He studied Electrical Engineering at TU Dresden, Germany, and received his Engineering Diploma degree in 2005. As external doctoral candidate at the Laboratory of Control Theory of TU Dresden his research focused on invariant feedback design for nonlinear (finite-dimensional) control systems possessing Lie symmetries employing a differential-

geometric approach to symmetries of nonlinear systems. He received his doctorate degree (summa cum laude) in 2011 and joined Younicos AG – a Berlin-based pioneer in battery storage systems and hybrids – serving in leading engineering roles and as member of the senior management team before the acquisition by Aggreko in 2017. Among his current research interests are solutions for optimal control of high-penetration microgrids.